

CERTIFICATE OF CALIBRATION TEMPERATURE SENSOR

Certificate No. : 0824-26-HI-CAL-10

Customer Information

Company Name PT. Bhumi Jati Power
Address PLTU Tanjung Jati B Unit 5&6 Tubanan, Kembang, Jepara - Jawa Tengah
Contract No. C-BJP-26-0004-OTH

Instrument Information

KKS No.	60LAE01CT001	Range	0 ~ 400
Instrument Description	SUPERHEATER ATTEMPERATING SPRAY WATER TEMPERATURE 1	Unit	°C
Manufacture	YAMARI	Out. Signal	4 - 20 mA
Model / Serial Number	- / 5451608	Max. Deviation	4 °C
Instrument Location	BOILER 9TH FLOOR	Cal. Date	02-06-2026
		Temp. Element	Thermocouple Type E

Environment Condition

Temperature 27.1 °C Humidity 54 % RH

Calibration Result

As Found					As Left				
Input	Std Output	Output UUT	Deviation	Result	Input	Std Output	Output UUT	Deviation	Result
[°C]	[°C]	[°C]			[°C]	[°C]	[°C]		
40	39.600	39.900	0.300	Pass					
100	99.900	101.000	1.100	Pass					
200	199.800	202.100	2.300	Pass					
300	299.900	300.800	0.900	Pass					
400	401.200	403.100	1.900	Pass					

Visual Inspection (Checklist if OK)

Leak Check ☐ Tightness Check ☒ Corrosion Check ☒
Accessories Check ☒ Power Supply ☐

Standard Reference

Description	Serial Number	Certificate Number	Calibration Date
Temperature Calibrator Fluke 725	2815000	2256/25/KAL/06/2025	23-06-2025
DRY WELL CALIBRATOR ADDITEL 875	660TH19040016	S-25010822	22-08-2025

Calibration Method

0002/SOP_BJS/2025
Standard Operating Procedure of Calibration Temperature Element, Temperature Transmitter & Temperature Switch

This certificate comprises 2 pages

Date of issue, 06-06-2026

Customer Signature,



Erfan Nanda Gifari

Approved Signatory,



Ivan Hasan Ashari

Calibrated by,



Khabib Mundzirul Umam

Sertifikat ini berlaku untuk alat dengan nama, merek dan tipe / nomor seri yang dinyatakan diatas

This certificate applies only for the item specified above

Tidak dibenarkan mempublikasikan/memperbanyak sebagian isi sertifikat ini tanpa ijin PT. Hervitama Indonesia

This certificate shall not be produced/reproduced except in full without the written approval of PT. Hervitama Indonesia

*Sertifikat ini sah bila dibubuhi cap PT. Hervitama Indonesia dan ditandatangani oleh pejabat yang berwenang

This certificate is valid if it has approved and signed by authorized person