

## CERTIFICATE OF CALIBRATION DIFFERENTIAL PRESSURE TRANSMITTER

Certificate No. : 0356-24-HI-CAL-10C

### Customer Information

Company Name: PT. Bhumi Jati Power  
Address: PLTU Tanjung Jati B Unit 5&6 Tubanan, Kembang, Jepara - Jawa Tengah  
Contract No.: C-BJP-24-0013-OTH

### Instrument Information

KKS No.	60LAE02CF001	Range	0 ~ 250
Instrument Description	PRIMARY SUPERHEATER SPRAY WATER FLOW 1	Unit	mbar
Manufacture	YOKOGAWA	Out. Signal	4 - 20 mA
Model	EJX430A	Max. Error	0.5 %
Serial Number	91V500794	Cal. Date	20-05-2024
Instrument Location	BOILER 8TH FLOOR		

### Environment Condition

Temperature: 27.5 °C  
Humidity: 51 % RH

### Calibration Result

Data Reading (Transmitter)											
As Found						As Left					
Input	Std Output	Output UUT	Deviation	Error	Result	Input	Std Output	Output UUT	Deviation	Error	Result
[mbar]	[mA]	[mA]		[%]		[mbar]	[mA]	[mA]		[%]	
0.0	4.000	4.003	0.003	0.019	Pass						
62.5	8.000	8.006	0.006	0.038	Pass						
125.0	12.000	12.009	0.009	0.056	Pass						
187.5	16.000	16.008	0.008	0.050	Pass						
250.0	20.000	20.010	0.010	0.063	Pass						
150.0	20.000	20.010	0.010	0.063	Pass						
187.5	16.000	16.010	0.010	0.063	Pass						
125.0	12.000	12.005	0.005	0.031	Pass						
62.5	8.000	8.008	0.008	0.050	Pass						
0.0	4.000	4.003	0.003	0.019	Pass						

### Standard Reference

Description	Serial Number	Certificate Number	Calibration Date
Documenting Process Calibrator Fluke 754	56070038	S. 22 002 081	17-02-2022
Pressure Module Fluke 750PD4	4474073	S. 23 014 461	10-10-2023

### Calibration Method

0001/SOP\_BJS/2023  
Procedure of Calibration Pressure & Differential Transmitter

This certificate comprise of 1 page  
Date of issue, 21-05-2024

Customer Signature,



Ayrton Humardani Putradhi

Approved Signatory,



M. Taufiq Nur Fitriyan

INDONESIA

Calibrated by,



Falshol Anwar

Sertifikat ini berlaku untuk alat dengan nama, merek dan tipe / nomor seri yang dinyatakan diatas

This certificate applies only for the item specified above

Dilarang mengutip, memperbanyak dan / atau mempublikasikan isi sertifikat ini tanpa izin dari PT. Hervitama Indonesia

It is prohibited to copy, reproduce and / or publish the content of this Certificate without PT Hervitama Indonesia's approval

\*Sertifikat ini sah bila dibubuhi cap PT. Hervitama Indonesia dan ditandatangani oleh pejabat yang berwenang

This certificate is valid if it has approved and signed by authorized person

