

## CERTIFICATE OF CALIBRATION DIFFERENTIAL PRESSURE TRANSMITTER

Certificate No. : 0359-24-HI-CAL-10C

### Customer Information

Company Name: PT. Bhumi Jati Power  
 Address: PLTU Tanjung Jati B Unit 5&6 Tubanan, Kembang, Jepara - Jawa Tengah  
 Contract No.: C-BJP-24-0013-OTH

### Instrument Information

KKS No.	60LAE03CF001	Range	0 ~ 889
Instrument Description	SECONDARY SUPERHEATER SPRAY WATER FLOW 1	Unit	mbar
Manufacture	YOKOGAWA	Out. Signal	4 - 20 mA
Model	EJX430A	Max. Error	0.5 %
Serial Number	91V500797	Cal. Date	20-05-2024
Instrument Location	BOILER 9TH FLOOR		

### Environment Condition

Temperature: 27.3 °C  
 Humidity: 50 % RH

### Calibration Result

Data Reading (Transmitter)											
As Found						As Left					
Input	Std Output	Output UUT	Deviation	Error	Result	Input	Std Output	Output UUT	Deviation	Error	Result
[mbar]	[mA]	[mA]		[%]		[mbar]	[mA]	[mA]		[%]	
0.0	4.000	3.996	-0.004	-0.025	Pass						
222.3	8.003	7.999	-0.004	-0.025	Pass						
444.5	12.000	12.001	0.001	0.006	Pass						
666.8	16.000	16.000	0.000	0.000	Pass						
889.0	20.000	20.002	0.002	0.012	Pass						
889.0	20.000	20.002	0.002	0.012	Pass						
666.8	16.000	16.003	0.003	0.019	Pass						
444.5	12.000	12.002	0.002	0.013	Pass						
222.3	8.000	7.998	-0.002	-0.012	Pass						
0.0	4.002	3.996	-0.006	-0.037	Pass						

### Standard Reference

Description	Serial Number	Certificate Number	Calibration Date
Documenting Process Calibrator Fluke 754	56070038	S. 22 002 081	17-02-2022
Pressure Module Fluke 750PD4	4474073	S. 23 014 461	10-10-2023

### Calibration Method

0001/SOP\_BJS/2023  
 Procedure of Calibration Pressure & Differential Transmitter

This certificate comprise of 1 page  
 Date of issue, 21-05-2024

Customer Signature,



Ayrton Humardani Putradhi

HERVITAMA  
 Accredited Laboratory



M. Taufiq Nur Fitriyan  
 INDONESIA

Calibrated by,



Faishol Anwar

Sertifikat ini berlaku untuk alat dengan nama, merek dan tipe / nomor seri yang dinyatakan diatas

This certificate applies only for the item specified above

Dilarang mengutip, memperbanyak dan / atau mempublikasikan isi sertifikat ini tanpa izin dari PT. Hervitama Indonesia  
 It is prohibited to copy, reproduce and / or publish the content of this Certificate without PT Hervitama Indonesia's approval

\*Sertifikat ini sah bila dibubuhi cap PT. Hervitama Indonesia dan ditandatangani oleh pejabat yang berwenang

This certificate is valid if it has approved and signed by authorized person

