

## CERTIFICATE OF CALIBRATION DIFFERENTIAL PRESSURE TRANSMITTER

Certificate No. : 0361-24-HI-CAL-10C

### Customer Information

Company Name: PT. Bhumi Jati Power  
Address: PLTU Tanjung Jati B Unit 5&6 Tubanan, Kembang, Jepara - Jawa Tengah  
Contract No.: C-BJP-24-0013-OTH

### Instrument Information

KKS No.	60LAE03CF003	Range	0 ~ 889
Instrument Description	SECONDARY SUPERHEATER SPRAY WATER FLOW 3	Unit	mbar
Manufacture	YOKOGAWA	Out. Signal	4 - 20 mA
Model	EJX430A	Max. Error	0.5 %
Serial Number	91V500799	Cal. Date	20-05-2024
Instrument Location	BOILER 9TH FLOOR		

### Environment Condition

Temperature: 27.3 °C  
Humidity: 50 % RH

### Calibration Result

Data Reading (Transmitter)											
As Found						As Left					
Input	Std Output	Output UUT	Deviation	Error	Result	Input	Std Output	Output UUT	Deviation	Error	Result
[mbar]	[mA]	[mA]		[%]		[mbar]	[mA]	[mA]		[%]	
0.0	4.000	3.994	-0.006	-0.037	Pass						
222.3	8.000	7.994	-0.006	-0.038	Pass						
444.5	12.000	11.995	-0.005	-0.031	Pass						
666.8	16.000	15.998	-0.002	-0.013	Pass						
889.0	20.000	19.999	-0.001	-0.006	Pass						
889.0	20.000	19.999	-0.001	-0.006	Pass						
666.8	16.000	16.003	0.003	0.019	Pass						
444.5	12.000	12.001	0.001	0.006	Pass						
222.3	8.000	7.993	-0.007	-0.044	Pass						
0.0	4.000	3.993	-0.007	-0.044	Pass						

### Standard Reference

Description	Serial Number	Certificate Number	Calibration Date
Documenting Process Calibrator Fluke 754	56070038	S. 22 002 081	17-02-2022
Pressure Module Fluke 750PD4	4474073	S. 23 014 461	10-10-2023

### Calibration Method

0001/SOP\_BJS/2023  
Procedure of Calibration Pressure & Differential Transmitter

This certificate comprise of 1 page  
Date of issue, 21-05-2024

Customer Signature,



Ayrton Humardani Putradhi

Authorized Signatory,



M. Taufiq Nur Finyan  
INDONESIA

Calibrated by,



Faishol Anwar

Sertifikat ini berlaku untuk alat dengan nama, merek dan tipe / nomor seri yang dinyatakan diatas

This certificate applies only for the item specified above

Dilarang mengutip, memperbanyak dan / atau mempublikasikan isi sertifikat ini tanpa izin dari PT. Hervitama Indonesia

It is prohibited to copy, reproduce and / or publish the content of this Certificate without PT Hervitama Indonesia's approval

\*Sertifikat ini sah bila dibubuhi cap PT. Hervitama Indonesia dan ditandatangani oleh pejabat yang berwenang

This certificate is valid if it has approved and signed by authorized person

