

## CERTIFICATE OF CALIBRATION PRESSURE TRANSMITTER

Certificate No. : 0363-24-HI-CAL-10C

### Customer Information

Company Name PT. Bhumi Jati Power  
Address PLTU Tanjung Jati B Unit 5&6 Tubanan, Kembang, Jepara - Jawa Tengah  
Contract No. C-BJP-24-0013-OTH

### Instrument Information

KKS No.	60LAF03CP001	Range	0 ~ 250
Instrument Description	REHEATER ATTEMPERATING SPRAY WATER PRESSURE	Unit	barg
Manufacture	YOKOGAWA	Out. Signal	4 - 20 mA
Model	EJX440A	Max. Error	0.5 %
Serial Number	91V500968	Cal. Date	22-05-2024
Instrument Location	TURBINE 2ND FLOOR		

### Environment Condition

Temperature 32 °C  
Humidity 65 % RH

### Calibration Result

Data Reading (Transmitter)											
As Found						As Left					
Input	Std Output	Output UUT	Deviation	Error	Result	Input	Std Output	Output UUT	Deviation	Error	Result
[barg]	[mA]	[mA]		[%]		[barg]	[mA]	[mA]		[%]	
0.00	4.000	4.000	0.000	0.000	Pass						
62.54	8.003	7.999	-0.004	-0.025	Pass						
125.00	12.000	11.998	-0.002	-0.013	Pass						
187.540	16.003	15.999	-0.004	-0.025	Pass						
250.00	20.000	20.001	0.001	0.006	Pass						
250.00	20.000	20.001	0.001	0.006	Pass						
187.540	16.003	15.999	-0.004	-0.025	Pass						
125.00	12.000	12.001	0.001	0.006	Pass						
62.54	8.003	8.001	-0.002	-0.013	Pass						

### Standard Reference

Description	Serial Number	Certificate Number	Calibration Date
Documenting Process Calibrator Fluke 754	3611011	S. 22 011 747	23-09-2023
PRESSURE MODULE P31	4472839	S. 23 004 595	27-03-2023

### Calibration Method

0001/SOP\_BJS/2023  
Procedure of Calibration Pressure & Differential Transmitter

This certificate comprise of 1 page  
Date of issue, 23-05-2024

Customer Signature,




Ayrton Humardani Putradhi

Approved by,



M. Taufiq Nur Fitriyan  
INDONESIA

Calibrated by,



Handi Suryawinata

Sertifikat ini berlaku untuk alat dengan nama, merek dan tipe / nomor seri yang dinyatakan diatas

*This certificate applies only for the item specified above*

Dilarang mengutip, memperbanyak dan / atau mempublikasikan isi sertifikat ini tanpa izin dari PT. Hervitama Indonesia

*It is prohibited to copy, reproduce and / or publish the content of this Certificate without PT Hervitama Indonesia's approval*

\*Sertifikat ini sah bila dibubuhi cap PT. Hervitama Indonesia dan ditandatangani oleh pejabat yang berwenang

*This certificate is valid if it has approved and signed by authorized person*

