

CERTIFICATE OF CALIBRATION TEMPERATURE SENSOR

Certificate No. : 0609-24-HI-CAL-10D

Customer Information

Company Name : PT. Bhumi Jati Power
 Address : PLTU Tanjung Jati B Unit 5&6 Tubanan, Kembang, Jepara - Jawa Tengah
 Contract No. : C-BJP-24-0013-OTH

Instrument Information

KKS No.	60LAV22CT010	Range	0 ~ 100
Instrument Description	BFPT B MAIN OIL COOLER OUTLET OIL TEMPERATURE 2	Unit	°C
Manufacture	YAMARI	Out. Signal	4 - 20 mA
Model	-	Max. Deviation	1.7 °C (JIS)
Serial Number	5346947	Cal. Date	17-05-2024
Instrument Location	TURBINE UNDER GROUND	Temp. Element	Thermocouple Type E

Environment Condition

Temperature : 29.7 °C
 Humidity : 64 % RH

Calibration Result

As Found					As Left				
Input	Std Output	Output UUT	Deviation	Result	Input	Std Output	Output UUT	Deviation	Result
[°C]	[°C]	[°C]			[°C]	[°C]	[°C]		
40	40.020	40.000	-0.020	Pass					
45	45.000	45.000	0.000	Pass					
50	50.000	50.100	0.100	Pass					
75	75.020	75.500	0.480	Pass					
100	100.000	100.800	0.800	Pass					

Standard Reference

Description	Serial Number	Certificate Number	Calibration Date
Documenting Process Calibrator Fluke 754	43550006	S. 22 022 080	21-02-2022
DRYBLOCK ADDITEL 875	660TH190400016	S. 23 008 476 /P	03-07-2023

Calibration Method

0002/SOP_BJS/2023
 Procedure of Calibration Temperature Element and Temperature Transmitter

This certificate comprise of 1 page
 Date of issue, 18-05-2024

Customer Signature,



Ayrton Humardani Putradhi

Approved Signatory,



M.INDONESIArian

Calibrated by,



Khabib Mundzirul Umam

Sertifikat ini berlaku untuk alat dengan nama, merek dan tipe / nomor seri yang dinyatakan diatas
 This certificate applies only for the item specified above
 Dilarang mengutip, memperbanyak dan / atau mempublikasikan isi sertifikat ini tanpa izin dari PT. Hervitama Indonesia
 It is prohibited to copy, reproduce and / or publish the content of this Certificate without PT Hervitama Indonesia's approval
 *Sertifikat ini sah bila dibubuhi cap PT. Hervitama Indonesia dan ditandatangani oleh pejabat yang berwenang
 This certificate is valid if it has approved and signed by authorized person