

## CERTIFICATE OF CALIBRATION PRESSURE TRANSMITTER

Certificate No. : 0364-24-HI-CAL-10C

### Customer Information

Company Name PT. Bhumi Jati Power  
 Address PLTU Tanjung Jati B Unit 5&6 Tubanan, Kembang, Jepara - Jawa Tengah  
 Contract No. C-BJP-24-0013-OTH

### Instrument Information

KKS No.	60LAV31CP005	Range	0 ~ 8
Instrument Description	BFPT A LUBE OIL PRESSURE	Unit	barg
Manufacture	YOKOGAWA	Out. Signal	4 - 20 mA
Model	EJX430A	Max. Error	0.5 %
Serial Number	91UB03609	Cal. Date	11-05-2024
Instrument Location	TURBINE 1ST FLOOR		

### Environment Condition

Temperature 32 °C  
 Humidity 65 % RH

### Calibration Result

Data Reading (Transmitter)											
As Found						As Left					
Input	Std Output	Output UUT	Deviation	Error	Result	Input	Std Output	Output UUT	Deviation	Error	Result
[barg]	[mA]	[mA]		[%]		[barg]	[mA]	[mA]		[%]	
0.000	4.000	3.993	-0.007	-0.044	Pass						
2.006	8.000	8.024	0.024	0.150	Pass						
4.006	12.000	12.018	0.018	0.112	Pass						
6.005	16.000	16.008	0.008	0.050	Pass						
8.005	20.000	20.013	0.013	0.081	Pass						
8.005	20.000	20.013	0.013	0.081	Pass						
6.005	16.000	16.007	0.007	0.044	Pass						
4.006	12.000	12.017	0.017	0.106	Pass						
2.006	8.000	8.015	0.015	0.094	Pass						
0.000	4.000	3.995	-0.005	-0.031	Pass						

### Standard Reference

Description	Serial Number	Certificate Number	Calibration Date
Documenting Process Calibrator Fluke 754	3611011	S. 22 011 747	23-09-2023
Fluke Pressure Module 700P08	14070183	S. 23 004 594	27-03-2023

### Calibration Method

0001/SOP\_BJS/2023  
 Procedure of Calibration Pressure & Differential Transmitter

This certificate comprise of 1 page  
 Date of issue, 12-05-2024

Customer Signature,

Ayrton Humardani Putradhi

Approved Signatory,

M. Taufiq Nur Fitriyan  
 INDONESIA

Calibrated by,

Handi Suryawinata

Sertifikat ini berlaku untuk alat dengan nama, merek dan tipe / nomor seri yang dinyatakan diatas

*This certificate applies only for the item specified above*

Dilarang mengutip, memperbanyak dan / atau mempublikasikan isi sertifikat ini tanpa izin dari PT. Hervitama Indonesia  
 It is prohibited to copy, reproduce and / or publish the content of this Certificate without PT Hervitama Indonesia's approval

\*Sertifikat ini sah bila dibubuhi cap PT. Hervitama Indonesia dan ditandatangani oleh pejabat yang berwenang

*This certificate is valid if it has approved and signed by authorized person*

