

**CERTIFICATE OF CALIBRATION**  
**PRESSURE SWITCH**

Certificate No. : 0057-26-HI-CAL-10

**Customer Information**

Company Name PT. Bhumi Jati Power  
Address PLTU Tanjung Jati B Unit 5&6 Tubanan, Kembang, Jepara - Jawa Tengah  
Contract No. C-BJP-26-0004-OTH

**Instrument Information**

|                        |                                |           |            |
|------------------------|--------------------------------|-----------|------------|
| KKS No.                | 60LAV31CP310                   | Range     | 0.2 - 2    |
| Instrument Description | BFPT A LUBE OIL PRESSURE LOW 2 | Set       | 0.275      |
| Manufacture            | NAGANO KEIKI                   | Reset     | 0.478      |
| Model / Serial Number  | CB33 / W12110                  | Unit      | bar g      |
| Instrument Location    | TURBINE 1ST FLOOR              | MPE       | ± 0.009    |
|                        |                                | Cal. Date | 02-06-2026 |

**Environment Condition**

Temperature 31 °C Humidity 72 % RH

**Calibration Result**

| Data Reading (Switch) |       |          |         |       |          |
|-----------------------|-------|----------|---------|-------|----------|
| As Found              |       |          | As Left |       |          |
| Set                   | Reset | Deadband | Set     | Reset | Deadband |
| 0.277                 | 0.484 | 0.207    |         |       |          |
| 0.276                 | 0.471 | 0.195    |         |       |          |
| 0.276                 | 0.472 | 0.196    |         |       |          |

**Visual Inspection (Checklist if OK)**

|                   |                                     |                 |                                     |                 |                                     |
|-------------------|-------------------------------------|-----------------|-------------------------------------|-----------------|-------------------------------------|
| Leak Check        | <input checked="" type="checkbox"/> | Tightness Check | <input checked="" type="checkbox"/> | Corrosion Check | <input checked="" type="checkbox"/> |
| Accessories Check | <input checked="" type="checkbox"/> | Power Supply    | <input checked="" type="checkbox"/> |                 |                                     |

**Standard Reference**

| Description                 | Serial Number | Certificate Number   | Calibration Date |
|-----------------------------|---------------|----------------------|------------------|
| DOCUMENTING PROCESS         | 2448033       | 4482/25/EX/10/2025   | 26-09-2025       |
| CALIBRATOR FLUKE 754        |               |                      |                  |
| FLUKE PRESURE MODULE 750PD6 | 6094437       | 02170/GQI-Sert/03/26 | 09-03-2026       |

**Calibration Method**

0003/SOP\_BJS/2025  
Standard Operating Procedure of Calibration Pressure Switch

This certificate comprises 2 pages  
Date of issue, 06-06-2026

Customer Signature,

Approved Signatory,

Calibrated by,

Ayrtan Humardani Putradhi

Ivan Hasan Ashari

Ryan Franki Risdianto

Sertifikat ini berlaku untuk alat dengan nama, merek dan tipe / nomor seri yang dinyatakan diatas

*This certificate applies only for the item specified above*

Tidak dibenarkan mempublikasikan/memperbanyak sebagian isi sertifikat ini tanpa ijin PT. Hervitama Indonesia

*This certificate shall not be produced/reproduced except in full without the written approval of PT. Hervitama Indonesia*

*\*Sertifikat ini sah bila dibubuhi cap PT. Hervitama Indonesia dan ditandatangani oleh pejabat yang berwenang*

*This certificate is valid if it has approved and signed by authorized person*