

## CERTIFICATE OF CALIBRATION PRESSURE SWITCH

Certificate No. : 0501-24-HI-CAL-10B

### Customer Information

Company Name PT. Bhumi Jati Power  
Address PLTU Tanjung Jati B Unit 5&6 Tubanan, Kembang, Jepara - Jawa Tengah  
Contract No. C-BJP-24-0013-OTH

### Instrument Information

|                        |                                |           |            |
|------------------------|--------------------------------|-----------|------------|
| KKS No.                | 60LAV32CP305                   | Range     | 0.2 - 2    |
| Instrument Description | BFPT B LUBE OIL PRESSURE LOW 1 | Set       | 0.275      |
| Manufacture            | NAGANO KEIKI                   | Reset     | 0.482      |
| Model                  | CB33                           | Unit      | barg       |
| Serial Number          | W12112                         | MPE       | ± 0.009    |
| Instrument Location    | TURBINE 1ST FLOOR              | Cal. Date | 11-05-2024 |

### Environment Condition

Temperature 28.3 °C  
Humidity 51 % RH

### Calibration Result

| Data Reading (Switch) |       |          |         |       |          |
|-----------------------|-------|----------|---------|-------|----------|
| As Found              |       |          | As Left |       |          |
| Set                   | Reset | Deadband | Set     | Reset | Deadband |
| 0.275                 | 0.492 | 0.217    |         |       |          |
| 0.276                 | 0.490 | 0.214    |         |       |          |
| 0.275                 | 0.459 | 0.184    |         |       |          |

### Standard Reference

| Description                              | Serial Number | Certificate Number | Calibration Date |
|--|---------------|--------------------|------------------|
| Documenting Process Calibrator Fluke 754 | 56070038      | S. 22 002 081      | 17-02-2022       |
| Pressure Module Fluke 750PD4             | 4474073       | S. 23 014 461      | 10-10-2023       |

### Calibration Method

0003/SOP\_BJS/2023  
Procedure of Calibration Pressure Switch

This certificate comprise of 1 page  
Date of issue, 12-05-2024

Customer Signature,



Ayrton Humardani Putradhi

Approved Signatory,



M. Irfan Nur Fitriyan

Calibrated by,



Faihsol Anwar

Sertifikat ini berlaku untuk alat dengan nama, merek dan tipe / nomor seri yang dinyatakan diatas

*This certificate applies only for the item specified above*

Dilarang mengutip, memperbanyak dan / atau mempublikasikan isi sertifikat ini tanpa izin dari PT. Hervitama Indonesia

*It is prohibited to copy, reproduce and / or publish the content of this Certificate without PT Hervitama Indonesia's approval*

\*Sertifikat ini sah bila dibubuhi cap PT. Hervitama Indonesia dan ditandatangani oleh pejabat yang berwenang

*This certificate is valid if it has approved and signed by authorized person*

