

CERTIFICATE OF CALIBRATION

PRESSURE SWITCH

Certificate No. : 0059-26-HI-CAL-10

Customer Information

Company Name

Address

Contract No.

PT. Bhumi Jati Power

PLTU Tanjung Jati B Unit 5&6 Tubanan, Kembang, Jepara - Jawa Tengah

C-BJP-26-0004-OTH

Instrument Information

KKS No.

Instrument Description

Manufacture

Model / Serial Number

Instrument Location

60LAV32CP305

BFPT B LUBE OIL PRESSURE LOW 1

NAGANO KEIKI

CB33 / W12112

TURBINE 1ST FLOOR

Range

Set

Reset

Unit

MPE

Cal. Date

0.2 - 2

0.275

0.482

bar g

± 0.009

02-06-2026

Environment Condition

Temperature

Humidity

32 °C

71 % RH

Calibration Result

Data Reading (Switch)					
As Found			As Left		
Set	Reset	Deadband	Set	Reset	Deadband
0.279	0.484	0.205			
0.279	0.483	0.204			
0.279	0.484	0.205			

Visual Inspection (Checklist if OK)

Leak Check

Accessories Check

Tightness Check

Power Supply

Corrosion Check

☒

☒

☒

☒

☒

Standard Reference

Description	Serial Number	Certificate Number	Calibration Date
DOCUMENTING PROCESS	2448033	4482/25/EX/10/2025	26-09-2025
CALIBRATOR FLUKE 754			
FLUKE PRESURE MODULE 750PD6	6094437	02170/GQI-Sert/03/26	09-03-2026

Calibration Method

0003/SOP_BJS/2025

Standard Operating Procedure of Calibration Pressure Switch

This certificate comprises 2 pages

Date of issue, 06-06-2026

Customer Signature,

Approved Signatory,

Calibrated by,



Ayrtan Humardani Putradhi



Ivan Hasan Ashari



Ryan Franki Risdianto

Sertifikat ini berlaku untuk alat dengan nama, merek dan tipe / nomor seri yang dinyatakan diatas

This certificate applies only for the item specified above

Tidak dibenarkan mempublikasikan/memperbanyak sebagian isi sertifikat ini tanpa ijin PT. Hervitama Indonesia

This certificate shall not be produced/reproduced except in full without the written approval of PT. Hervitama Indonesia

*Sertifikat ini sah bila dibubuhi cap PT. Hervitama Indonesia dan ditandatangani oleh pejabat yang berwenang

This certificate is valid if it has approved and signed by authorized person

