

CERTIFICATE OF CALIBRATION PRESSURE SWITCH

Certificate No. : 0502-24-HI-CAL-10B

Customer Information

Company Name PT. Bhumi Jati Power
 Address PLTU Tanjung Jati B Unit 5&6 Tubanan, Kembang, Jepara - Jawa Tengah
 Contract No. C-BJP-24-0013-OTH

Instrument Information

KKS No.	60LAV32CP310	Range	0.2 - 2
Instrument Description	BFPT B LUBE OIL PRESSURE LOW 2	Set	0.277
Manufacture	NAGANO KEIKI	Reset	0.482
Model	CB33	Unit	barg
Serial Number	W12113	MPE	± 0.009
Instrument Location	TURBINE 1ST FLOOR	Cal. Date	11-05-2024

Environment Condition

Temperature 28.1 °C
 Humidity 52 % RH

Calibration Result

Data Reading (Switch)					
As Found			As Left		
Set	Reset	Deadband	Set	Reset	Deadband
0.283	0.482	0.199	0.276	0.484	0.208
0.283	0.482	0.199	0.275	0.480	0.205
0.283	0.482	0.199	0.277	0.489	0.212

Standard Reference

Description	Serial Number	Certificate Number	Calibration Date
Documenting Process Calibrator Fluke 754	56070038	S. 22 002 081	17-02-2022
Pressure Module Fluke 750PD4	4474073	S. 23 014 461	10-10-2023

Calibration Method

0003/SOP_BJS/2023
 Procedure of Calibration Pressure Switch

This certificate comprise of 1 page
 Date of issue, 12-05-2024

Customer Signature,




Ayrton Humardani Putradhi

Approved Signatory,



M. Fauz Nur Fitriyan

Calibrated by,



Faishol Anwar

Sertifikat ini berlaku untuk alat dengan nama, merek dan tipe / nomor seri yang dinyatakan diatas

This certificate applies only for the item specified above

Dilarang mengutip, memperbanyak dan / atau mempublikasikan isi sertifikat ini tanpa izin dari PT. Hervitama Indonesia
It is prohibited to copy, reproduce and / or publish the content of this Certificate without PT Hervitama Indonesia's approval

**Sertifikat ini sah bila dibubuhi cap PT. Hervitama Indonesia dan ditandatangani oleh pejabat yang berwenang*

This certificate is valid if it has approved and signed by authorized person

