

CERTIFICATE OF CALIBRATION
TEMPERATURE SENSOR

Certificate No. : 0835-26-HI-CAL-10

Customer Information

Company Name PT. Bhumi Jati Power
Address PLTU Tanjung Jati B Unit 5&6 Tubanan, Kembang, Jepara - Jawa Tengah
Contract No. C-BJP-26-0004-OTH

Instrument Information

KKS No.	60LAV41CT002	Range	0 ~ 100
Instrument Description	TBFP BP THRUST BRG. RETURN OIL TEMP.	Unit	°C
Manufacture	OKAZAKI	Out. Signal	4 - 20 mA
Model / Serial Number	TS / 1511213	Max. Deviation	1.7 °C (JIS)
Instrument Location	TURBINE 1ST FLOOR	Cal. Date	06-06-2026
		Temp. Element	RTD

Environment Condition

Temperature 27.7 °C Humidity 55 % RH

Calibration Result

As Found					As Left				
Input	Std Output	Output UUT	Deviation	Result	Input	Std Output	Output UUT	Deviation	Result
[°C]	[°C]	[°C]			[°C]	[°C]	[°C]		
40	39.780	40.010	0.230	Pass					
45	44.830	45.110	0.280	Pass					
50	49.830	49.980	0.150	Pass					
75	74.950	75.500	0.550	Pass					
100	99.840	99.920	0.080	Pass					

Visual Inspection (Checklist if OK)

Leak Check	☐	Tightness Check	☒	Corrosion Check	☒
Accessories Check	☒	Power Supply	☐		

Standard Reference

Description	Serial Number	Certificate Number	Calibration Date
Temperature Calibrator Fluke 725	2815000	2256/25/KAL/06/2025	23-06-2025
DRY WELL CALIBRATOR ADDITEL 875	660TH19040016	S-25010822	22-08-2025

Calibration Method

0002/SOP_BJS/2025

Standard Operating Procedure of Calibration Temperature Element, Temperature Transmitter & Temperature Switch

This certificate comprises 2 pages

Date of issue, 10-06-2026

Customer Signature,

Ayrton Humardani Putradhi

HERVITAMA
Approved by,
INDONESIA
Ivan Hasan Ashari

Calibrated by,

Khabib Mundzirul Umam

Sertifikat ini berlaku untuk alat dengan nama, merek dan tipe / nomor seri yang dinyatakan diatas

This certificate applies only for the item specified above

Tidak dibenarkan mempublikasikan/memperbanyak sebagian isi sertifikat ini tanpa ijin PT. Hervitama Indonesia

This certificate shall not be produced/reproduced except in full without the written approval of PT. Hervitama Indonesia

*Sertifikat ini sah bila dibubuhi cap PT. Hervitama Indonesia dan ditandatangani oleh pejabat yang berwenang

This certificate is valid if it has approved and signed by authorized person

