

CERTIFICATE OF CALIBRATION PRESSURE TRANSMITTER

Certificate No. : 0366-24-HI-CAL-10C

Customer Information

Company Name: PT. Bumi Jati Power
 Address: PLTU Tanjung Jati B Unit 5&6 Tubanan, Kembang, Jepara - Jawa Tengah
 Contract No.: C-BJP-24-0013-OTH

Instrument Information

KKS No.	60LAV50CP002	Range	0 ~ 6
Instrument Description	MBFP LUB OIL PRESS 1	Unit	barg
Manufacture	YOKOGAWA	Out. Signal	4 - 20 mA
Model	EJX430A	Max. Error	0.5 %
Serial Number	91UB02412	Cal. Date	11-05-2024
Instrument Location	TURBINE 1ST FLOOR		

Environment Condition

Temperature: 32 °C
 Humidity: 65 % RH

Calibration Result

Data Reading (Transmitter)											
As Found						As Left					
Input	Std Output	Output UUT	Deviation	Error	Result	Input	Std Output	Output UUT	Deviation	Error	Result
[barg]	[mA]	[mA]		[%]		[barg]	[mA]	[mA]		[%]	
0.000	4.000	3.989	-0.011	-0.069	Pass						
1.503	8.000	8.013	0.013	0.081	Pass						
3.006	12.000	12.029	0.029	0.181	Pass						
4.502	16.000	16.012	0.012	0.075	Pass						
6.005	20.000	20.022	0.022	0.137	Pass						
6.005	20.000	20.022	0.022	0.137	Pass						
4.502	16.000	15.995	-0.005	-0.031	Pass						
3.006	12.000	12.020	0.020	0.125	Pass						
1.503	8.000	8.024	0.024	0.150	Pass						
0.000	4.000	4.010	0.010	0.062	Pass						

Standard Reference

Description	Serial Number	Certificate Number	Calibration Date
Documenting Process Calibrator Fluke 754	3611011	S. 22 011 747	23-09-2023
Fluke Pressure Module 700P08	14070183	S. 23 004 594	27-03-2023

Calibration Method

0001/SOP_BJS/2023
 Procedure of Calibration Pressure & Differential Transmitter

This certificate comprise of 1 page
 Date of issue, 12-05-2024

Customer Signature,




Ayrton Humardani Putradhi

HERVITAMA
 Approved Signatory,



M. Taufiq Nur Fitriyan

Calibrated by,



Handi Suryawinata

Sertifikat ini berlaku untuk alat dengan nama, merek dan tipe / nomor seri yang dinyatakan diatas
 This certificate applies only for the item specified above
 Dilarang mengutip, memperbanyak dan / atau mempublikasikan isi sertifikat ini tanpa izin dari PT. Hervitama Indonesia
 It is prohibited to copy, reproduce and / or publish the content of this Certificate without PT. Hervitama Indonesia's approval
 *Sertifikat ini sah bila dibubuhi cap PT. Hervitama Indonesia dan ditandatangani oleh pejabat yang berwenang
 This certificate is valid if it has approved and signed by authorized person

