

## CERTIFICATE OF CALIBRATION PRESSURE TRANSMITTER

Certificate No. : 0367-24-HI-CAL-10C

### Customer Information

Company Name PT. Bhumi Jati Power  
 Address PLTU Tanjung Jati B Unit 5&6 Tubanan, Kembang, Jepara - Jawa Tengah  
 Contract No. C-BJP-24-0013-OTH

### Instrument Information

KKS No. 60LAV50CP003 Range 0 – 6  
 Instrument Description MBFP LUB OIL PRESS 2 Unit barg  
 Manufacture YOKOGAWA Out. Signal 4 - 20 mA  
 Model EJX430A Max. Error 0.5 %  
 Serial Number 91UB02413 Cal. Date 11-05-2024  
 Instrument Location TURBINE 1ST FLOOR

### Environment Condition

Temperature 32 °C  
 Humidity 65 % RH

### Calibration Result

Data Reading (Transmitter)											
As Found						As Left					
Input	Std Output	Output UUT	Deviation	Error	Result	Input	Std Output	Output UUT	Deviation	Error	Result
[barg]	[mA]	[mA]		[%]		[barg]	[mA]	[mA]		[%]	
0.000	4.000	3.992	-0.008	-0.050	Pass						
1.503	8.000	7.995	-0.005	-0.031	Pass						
3.006	12.000	12.019	0.019	0.119	Pass						
4.502	16.000	15.984	-0.016	-0.100	Pass						
6.005	20.000	19.994	-0.006	-0.038	Pass						
6.005	20.000	19.994	-0.006	-0.038	Pass						
4.502	16.000	15.988	-0.012	-0.075	Pass						
3.006	12.000	11.984	-0.016	-0.100	Pass						
1.503	8.000	7.984	-0.016	-0.100	Pass						
0.000	4.000	4.002	0.002	0.012	Pass						

### Standard Reference

Description	Serial Number	Certificate Number	Calibration Date
Documenting Process Calibrator Fluke 754	3611011	S. 22 011 747	23-09-2023
Fluke Pressure Module 700P08	14070183	S. 23 004 594	27-03-2023

### Calibration Method

0001/SOP\_BJS/2023  
 Procedure of Calibration Pressure & Differential Transmitter

This certificate comprise of 1 page  
 Date of issue, 12-05-2024

Customer Signature,



Ayrton Humardani Putradhi

Approved Signatory,  
 HERVITAMA



M. Taufiq Nur Fitriyan

Calibrated by,



Handi Suryawinata

Sertifikat ini berlaku untuk alat dengan nama, merek dan tipe / nomor seri yang dinyatakan diatas  
 This certificate applies only for the item specified above  
 Dilarang mengutip, memperbanyak dan / atau mempublikasikan isi sertifikat ini tanpa izin dari PT. Hervitama Indonesia  
 It is prohibited to copy, reproduce and / or publish the content of this Certificate without PT. Hervitama Indonesia's approval  
 \*Sertifikat ini sah bila dibubuhi cap PT. Hervitama Indonesia dan ditandatangani oleh pejabat yang berwenang  
 This certificate is valid if it has approved and signed by authorized person

