

CERTIFICATE OF CALIBRATION PRESSURE TRANSMITTER

Certificate No. : 0368-24-HI-CAL-10C

Customer Information

Company Name: PT. Bhumi Jati Power
 Address: PLTU Tanjung Jati B Unit 5&6 Tubanan, Kembang, Jepara - Jawa Tengah
 Contract No.: C-BJP-24-0013-OTH

Instrument Information

KKS No.	60LAV50CP004	Range	0 ~ 6
Instrument Description	MBFP LUB OIL PRESS 3	Unit	barg
Manufacture	YOKOGAWA	Out. Signal	4 - 20 mA
Model	EJX430A	Max. Error	0.5 %
Serial Number	91UB02414	Cal. Date	11-05-2024
Instrument Location	TURBINE 1ST FLOOR		

Environment Condition

Temperature: 32 °C
 Humidity: 65 % RH

Calibration Result

Data Reading (Transmitter)											
As Found						As Left					
Input	Std Output	Output UUT	Deviation	Error	Result	Input	Std Output	Output UUT	Deviation	Error	Result
[barg]	[mA]	[mA]		[%]		[barg]	[mA]	[mA]		[%]	
0.000	4.000	4.001	0.001	0.006	Pass						
1.503	8.000	7.996	-0.004	-0.025	Pass						
3.006	12.000	11.999	-0.001	-0.006	Pass						
4.502	16.000	16.012	0.012	0.075	Pass						
6.005	20.000	20.007	0.007	0.044	Pass						
6.005	20.000	20.007	0.007	0.044	Pass						
4.502	16.000	15.981	-0.019	-0.119	Pass						
3.006	12.000	11.992	-0.008	-0.050	Pass						
1.503	8.000	7.992	-0.008	-0.050	Pass						
0.000	4.000	3.992	-0.008	-0.050	Pass						

Standard Reference

Description	Serial Number	Certificate Number	Calibration Date
Documenting Process Calibrator Fluke 754	3611011	S. 22 011 747	23-09-2023
Fluke Pressure Module 700P08	14070183	S. 23 004 594	27-03-2023

Calibration Method

0001/SOP_BJS/2023
 Procedure of Calibration Pressure & Differential Transmitter

This certificate comprise of 1 page
 Date of issue, 12-05-2024

Customer Signature,



Ayrtan Humardani Putradhi

Approved by,



M. Taufiq Nur Fitriyan
 INDONESIA

Calibrated by,



Handi Suryawinata

Sertifikat ini berlaku untuk alat dengan nama, merek dan tipe / nomor seri yang dinyatakan diatas

This certificate applies only for the item specified above

Dilarang mengutip, memperbanyak dan / atau mempublikasikan isi sertifikat ini tanpa izin dari PT. Hervitama Indonesia
It is prohibited to copy, reproduce and / or publish the content of this Certificate without PT Hervitama Indonesia's approval

*Sertifikat ini sah bila dibubuhi cap PT. Hervitama Indonesia dan ditandatangani oleh pejabat yang berwenang

This certificate is valid if it has approved and signed by authorized person

