

## CERTIFICATE OF CALIBRATION PRESSURE SWITCH

Certificate No. : 0507-24-HI-CAL-10B

### Customer Information

Company Name PT. Bhumi Jati Power  
Address PLTU Tanjung Jati B Unit 5&6 Tubanan, Kembang, Jepara - Jawa Tengah  
Contract No. C-BJP-24-0013-OTH

### Instrument Information

KKS No.	60LAX11CP320	Range	2 - 20
Instrument Description	BFPT A EMERGENCY OIL PRESSURE LOW 1	Set	5
Manufacture	NAGANO KEIKI	Reset	6.8
Model	CB33	Unit	barg
Serial Number	W12117	MPE	± 0.09
Instrument Location	TURBINE 1ST FLOOR	Cal. Date	11-05-2024

### Environment Condition

Temperature 28.1 °C  
Humidity 52 % RH

### Calibration Result

Data Reading (Switch)					
As Found			As Left		
Set	Reset	Deadband	Set	Reset	Deadband
5.075	6.837	1.762			
5.084	6.838	1.754			
5.084	6.836	1.752			

### Standard Reference

Description	Serial Number	Certificate Number	Calibration Date
Documenting Process Calibrator Fluke 754	56070038	S. 22 002 081	17-02-2022
Fluke Pressure Module 750PD27	6087359	S. 23 014 459	09-10-2023

### Calibration Method

0003/SOP\_BJS/2023  
Procedure of Calibration Pressure Switch

This certificate comprise of 1 page  
Date of issue, 12-05-2024

Customer Signature,




Ayrton Humardani Putradhi

Approved Signatory,



M. Taufiq Nur Fitriyan

Calibrated by,



Faishol Anwar

Sertifikat ini berlaku untuk alat dengan nama, merek dan tipe / nomor seri yang dinyatakan diatas

*This certificate applies only for the item specified above*

Dilarang mengutip, memperbanyak dan / atau mempublikasikan isi sertifikat ini tanpa izin dari PT. Hervitama Indonesia  
*It is prohibited to copy, reproduce and / or publish the content of this Certificate without PT Hervitama Indonesia's approval*

\*Sertifikat ini sah bila dibubuhi cap PT. Hervitama Indonesia dan ditandatangani oleh pejabat yang berwenang

*This certificate is valid if it has approved and signed by authorized person*

