

CERTIFICATE OF CALIBRATION PRESSURE SWITCH

Certificate No. : 0070-26-HI-CAL-10

Customer Information

Company Name PT. Bhumi Jati Power
 Address PLTU Tanjung Jati B Unit 5&6 Tubanan, Kembang, Jepara - Jawa Tengah
 Contract No. C-BJP-26-0004-OTH

Instrument Information

KKS No. 60LAX12CP315
 Instrument Description BFPT B EHC OIL PRESSURE LOW
 Manufacture NAGANO KEIKI
 Model / Serial Number CB33 / W12121
 Instrument Location TURBINE 1ST FLOOR

Range 2 - 20
 Set 7.9
 Reset 8.9
 Unit bar g
 MPE ± 0.09
 Cal. Date 26-05-2026

Environment Condition

Temperature 32 °C Humidity 70 % RH

Calibration Result

Data Reading (Switch)					
As Found			As Left		
Set	Reset	Deadband	Set	Reset	Deadband
7.867	8.821	0.954			
7.867	8.821	0.954			
7.867	8.821	0.954			

Visual Inspection (Checklist if OK)

Leak Check ☒ Tightness Check ☒ Corrosion Check ☒
 Accessories Check ☒ Power Supply ☒

Standard Reference

Description	Serial Number	Certificate Number	Calibration Date
DOCUMENTING PROCESS CALIBRATOR FLUKE 754	56070038	MAL 26031230	06-03-2026
PRESSURE MODULE FLK 750PD27	6087359	02172/GQI-Sert/03/26	09-03-2026

Calibration Method

0003/SOP_BJS/2025
 Standard Operating Procedure of Calibration Pressure Switch

This certificate comprises 2 pages
 Date of issue, 02-06-2026

Customer Signature,

Ayrtan Humardani Putradhi

Approved Signatory,
HERVITAMA

INDONESIA

Calibrated by,

Akhmad Nashoikhuddin

Sertifikat ini berlaku untuk alat dengan nama, merek dan tipe / nomor seri yang dinyatakan diatas

This certificate applies only for the item specified above

Tidak dibenarkan mempublikasikan/memperbanyak sebagian isi sertifikat ini tanpa ijin PT. Hervitama Indonesia

This certificate shall not be produced/reproduced except in full without the written approval of PT. Hervitama Indonesia

*Sertifikat ini sah bila dibubuhi cap PT. Hervitama Indonesia dan ditandatangani oleh pejabat yang berwenang

This certificate is valid if it has approved and signed by authorized person