

CERTIFICATE OF CALIBRATION PRESSURE SWITCH

Certificate No. : 0514-24-HI-CAL-10B

Customer Information

Company Name PT. Bhumi Jati Power
Address PLTU Tanjung Jati B Unit 5&6 Tubanan, Kembang, Jepara - Jawa Tengah
Contract No. C-BJP-24-0013-OTH

Instrument Information

KKS No.	60LAX12CP325	Range	2 - 20
Instrument Description	BFPT B EMERGENCY OIL PRESSURE LOW 2	Set	5
Manufacture	NAGANO KEIKI	Reset	6.8
Model	CB33	Unit	barg
Serial Number	W12124	MPE	± 0.09
Instrument Location	TURBINE 1ST FLOOR	Cal. Date	11-05-2024

Environment Condition

Temperature 32.3 °C
Humidity 65 % RH

Calibration Result

Data Reading (Switch)					
As Found			As Left		
Set	Reset	Deadband	Set	Reset	Deadband
5.075	6.757	1.682			
5.075	6.757	1.682			
5.075	6.757	1.682			

Standard Reference

Description	Serial Number	Certificate Number	Calibration Date
Documenting Process Calibrator Fluke 754	3611011	S. 22 011 747	23-09-2023
Fluke Pressure Module 700P08	14070183	S. 23 004 594	27-03-2023

Calibration Method

0003/SOP_BJS/2023
Procedure of Calibration Pressure Switch

This certificate comprise of 1 page
Date of issue, 12-05-2024

Customer Signature,




Ayrtan Humardani Putradhi

Approved Signatory
HERVITAMA



M. Taufiq Nur Fityan

Calibrated by,



Handi Suryawinata

Sertifikat ini berlaku untuk alat dengan nama, merek dan tipe / nomor seri yang dinyatakan diatas

This certificate applies only for the item specified above

Dilarang mengutip, memperbanyak dan / atau mempublikasikan isi sertifikat ini tanpa izin dari PT. Hervitama Indonesia

It is prohibited to copy, reproduce and / or publish the content of this Certificate without PT Hervitama Indonesia's approval

***Sertifikat ini sah bila dibubuhi cap PT. Hervitama Indonesia dan ditandatangani oleh pejabat yang berwenang**

This certificate is valid if it has approved and signed by authorized person

