

CERTIFICATE OF CALIBRATION PRESSURE TRANSMITTER

Certificate No. : 0374-24-HI-CAL-10C

Customer Information

Company Name PT. Bumi Jati Power
Address PLTU Tanjung Jati B Unit 5&6 Tubanan, Kembang, Jepara - Jawa Tengah
Contract No. C-BJP-24-0013-OTH

Instrument Information

KKS No.	60LBA11CP005	Range	0.3 ~ 300.3
Instrument Description	MAIN STEAM PRESSURE	Unit	barg
Manufacture	YOKOGAWA	Out. Signal	4 - 20 mA
Model	EJX440A	Max. Error	0.5 %
Serial Number	91V703035	Cal. Date	16-05-2024
Instrument Location	TURBINE 2ND FLOOR		

Environment Condition

Temperature 30.2 °C
Humidity 65 % RH

Calibration Result

Data Reading (Transmitter)											
As Found						As Left					
Input	Std Output	Output UUT	Deviation	Error	Result	Input	Std Output	Output UUT	Deviation	Error	Result
[barg]	[mA]	[mA]		[%]		[barg]	[mA]	[mA]		[%]	
0.34	4.001	3.993	-0.008	-0.050	Pass						
25.29	8.001	7.989	-0.012	-0.075	Pass						
50.31	12.001	11.987	-0.014	-0.087	Pass						
225.32	16.003	15.988	-0.015	-0.094	Pass						
300.34	20.001	19.999	-0.002	-0.013	Pass						
300.34	20.001	19.999	-0.002	-0.013	Pass						
225.32	16.003	15.991	-0.012	-0.075	Pass						
50.31	12.001	11.987	-0.014	-0.087	Pass						
25.29	8.001	7.993	-0.008	-0.050	Pass						
0.34	4.001	3.991	-0.010	-0.063	Pass						

Standard Reference


Description	Serial Number	Certificate Number	Calibration Date
Documenting Process Calibrator Fluke 754	3611011	S. 22 011 747	23-09-2023
PRESSURE MODULE P31	4472839	S. 23 004 595	27-03-2023

Calibration Method

0001/SOP_BJS/2023
Procedure of Calibration Pressure & Differential Transmitter

This certificate comprise of 1 page
Date of issue, 17-05-2024

Customer Signature,




Ayrtan Humardani Putradhi

Approved Signatory,



M. Taufiq Nur Fitriyan

Calibrated by,



Handi Suryawinata

Sertifikat ini berlaku untuk alat dengan nama, merek dan tipe / nomor seri yang dinyatakan diatas

This certificate applies only for the item specified above

Dilarang mengutip, memperbanyak dan / atau mempublikasikan isi sertifikat ini tanpa izin dari PT. Hervitama Indonesia
It is prohibited to copy, reproduce and / or publish the content of this Certificate without PT Hervitama Indonesia's approval

*Sertifikat ini sah bila dibubuhi cap PT. Hervitama Indonesia dan ditandatangani oleh pejabat yang berwenang

This certificate is valid if it has approved and signed by authorized person

