

CERTIFICATE OF CALIBRATION
DIFFERENTIAL PRESSURE TRANSMITTER

Certificate No. : 0450-26-HI-CAL-10

Customer Information

Company Name PT. Bhumi Jati Power
Address PLTU Tanjung Jati B Unit 5&6 Tubanan, Kembang, Jepara - Jawa Tengah
Contract No. C-BJP-26-0004-OTH

Instrument Information

KKS No. 60LBA11CP005 Range 0.30 ~ 300.30
Instrument Description MAIN STEAM PRESSURE Unit bar g
Manufacture YOKOGAWA Out. Signal 4 - 20 mA
Model / Serial Number EJX440A / 91V703035 Max. Error 0.5 %
Instrument Location TURBINE 2ND FLOOR Cal. Date 30-05-2026

Environment Condition

Temperature 31 °C Humidity 67 % RH

Calibration Result

As Found						As Left					
Input	Std Output	Output UUT	Deviation	Error	Result	Input	Std Output	Output UUT	Deviation	Error	Result
[bar g]	[mA]	[mA]		[%]		[bar g]	[mA]	[mA]		[%]	
0.340	4.002	4.002	0.000	0.000	Pass						
75.360	8.003	8.002	-0.001	-0.006	Pass						
150.310	12.000	12.000	0.000	0.000	Pass						
225.320	16.001	16.000	-0.001	-0.006	Pass						
300.340	20.002	20.001	-0.001	-0.006	Pass						
225.320	16.001	16.001	0.000	0.000	Pass						
150.310	12.000	12.001	0.001	0.006	Pass						
75.290	7.999	8.002	0.003	0.019	Pass						
0.340	4.002	4.002	0.000	0.000	Pass						

Visual Inspection (Checklist if OK)

Leak Check ☒ Tightness Check ☒ Corrosion Check ☒
Accessories Check ☒ Power Supply ☒

Standard Reference

Description	Serial Number	Certificate Number	Calibration Date
DOCUMENTING PROCESS CALIBRATOR FLUKE 754	56070038	MAL 26031230	06-03-2026
FLUKE PRESEURE MODULE 750P31	4472839	MAL 26031236	03-03-2026

Calibration Method

0001/SOP_BJS/2025
Standard Operating Procedure of Calibration Pressure & Differential Transmitter

This certificate comprises 2 pages
Date of issue, 04-06-2026

Customer Signature,

Ayrton Humardani Putradhi

HERVITAMA

INDONESIA
Ivan Hasan Ashari

Calibrated by,

Akhmad Nashoikhuddin

Sertifikat ini berlaku untuk alat dengan nama, merek dan tipe / nomor seri yang dinyatakan diatas

This certificate applies only for the item specified above

Tidak dibenarkan mempublikasikan/memperbanyak sebagian isi sertifikat ini tanpa ijin PT. Hervitama Indonesia

This certificate shall not be produced/reproduced except in full without the written approval of PT. Hervitama Indonesia

*Sertifikat ini sah bila dibubuhi cap PT. Hervitama Indonesia dan ditandatangani oleh pejabat yang berwenang

This certificate is valid if it has approved and signed by authorized person