

## CERTIFICATE OF CALIBRATION DIFFERENTIAL PRESSURE TRANSMITTER

Certificate No. : 0451-26-HI-CAL-10

### Customer Information

Company Name PT. Bhumi Jati Power  
Address PLTU Tanjung Jati B Unit 5&6 Tubanan, Kembang, Jepara - Jawa Tengah  
Contract No. C-BJP-26-0004-OTH

### Instrument Information

KKS No. 60LBB15CP005  
Instrument Description HOT REHEAT STEAM PRESSURE  
Manufacture YOKOGAWA  
Model / Serial Number EJX430A / 91V703367  
Instrument Location TURBINE 2ND FLOOR

Range 0.30 ~ 70.30  
Unit bar g  
Out. Signal 4 - 20 mA  
Max. Error 0.5 %  
Cal. Date 30-05-2026

### Environment Condition

Temperature 31 °C Humidity 67 % RH

### Calibration Result

| As Found |            |            |           |        |        | As Left |            |            |           |       |        |
|----------|------------|------------|-----------|--------|--------|---------|------------|------------|-----------|-------|--------|
| Input    | Std Output | Output UUT | Deviation | Error  | Result | Input   | Std Output | Output UUT | Deviation | Error | Result |
| [bar g]  | [mA]       | [mA]       |           | [%]    |        | [bar g] | [mA]       | [mA]       |           | [%]   |        |
| 0.280    | 4.009      | 4.000      | -0.009    | -0.056 | Pass   |         |            |            |           |       |        |
| 17.790   | 7.997      | 8.000      | 0.003     | 0.019  | Pass   |         |            |            |           |       |        |
| 35.300   | 12.000     | 12.003     | 0.003     | 0.019  | Pass   |         |            |            |           |       |        |
| 52.810   | 16.002     | 15.999     | -0.003    | -0.019 | Pass   |         |            |            |           |       |        |
| 70.330   | 20.006     | 20.000     | -0.006    | -0.038 | Pass   |         |            |            |           |       |        |
| 52.810   | 16.002     | 16.000     | -0.002    | -0.013 | Pass   |         |            |            |           |       |        |
| 35.300   | 12.000     | 12.004     | 0.004     | 0.025  | Pass   |         |            |            |           |       |        |
| 17.790   | 7.997      | 8.000      | 0.003     | 0.019  | Pass   |         |            |            |           |       |        |
| 0.340    | 4.009      | 4.000      | -0.009    | -0.056 | Pass   |         |            |            |           |       |        |

### Visual Inspection (Checklist if OK)

Leak Check ☒ Tightness Check ☒ Corrosion Check ☒  
Accessories Check ☒ Power Supply ☒

### Standard Reference

| Description                              | Serial Number | Certificate Number | Calibration Date |
|------------------------------------------|---------------|--------------------|------------------|
| DOCUMENTING PROCESS CALIBRATOR FLUKE 754 | 56070038      | MAL 26031230       | 06-03-2026       |
| FLUKE PRESEURE MODULE 750P31             | 4472839       | MAL 26031236       | 03-03-2026       |

### Calibration Method

0001/SOP\_BJS/2025  
Standard Operating Procedure of Calibration Pressure & Differential Transmitter

This certificate comprises 2 pages  
Date of issue, 04-06-2026

Customer Signature,

Ayrton Humardani Putradhi

HERVITAMA Laboratory,



INDONESIA  
Ivan Hasan Ashari

Calibrated by,

Akhmad Nashoikhuddin

Sertifikat ini berlaku untuk alat dengan nama, merek dan tipe / nomor seri yang dinyatakan diatas

This certificate applies only for the item specified above

Tidak dibenarkan mempublikasikan/memperbanyak sebagian isi sertifikat ini tanpa ijin PT. Hervitama Indonesia

This certificate shall not be produced/reproduced except in full without the written approval of PT. Hervitama Indonesia

\*Sertifikat ini sah bila dibubuhi cap PT. Hervitama Indonesia dan ditandatangani oleh pejabat yang berwenang

This certificate is valid if it has approved and signed by authorized person