

## REPORT OF INSPECTION ON-OFF VALVE

Certificate No. : 1230-24-HI-CAL-10J

### Customer Information

Company Name PT. Bumi Jati Power  
 Address PLTU Tanjung Jati B Unit 5&6 Tubanan, Kembang, Jepara - Jawa Tengah  
 Contract No. C-BJP-24-0014-OTH

### Instrument Information

KKS No. 60LBQ10AA820 Damping Time 0.18 s  
 Instrument Description HP HEATER 8 EXTRACTION NON RETURN VALVE OUTLET DRAIN VALVE Inspection Date 16-05-2024  
 Manufacture NAKAKITA  
 Model NS650  
 Serial Number 18CY0628  
 Instrument Location TURBINE 2ND FLOOR

### Environment Condition

Temperature 31 °C Traveling Time  
 Humidity 44 % RH Open to Close 00.46 s  
 Close to Open 01.51 s

### Stroke Result

Command	Feedback			
	Local		DCS	
	Open	Close	Open	Close
Close	-	OK	-	OK
Open	OK	-	OK	-

### Visual Inspection

Leak Check  OK  Not OK Tightness Check  OK  Not OK  
 Corrosion Condition  OK  Not OK Accessories Check  OK  Not OK  
 Air Regulator Check  OK  Not OK

### Remark

### Test Equipment

Description Serial Number Certificate Number Calibration Date  
 STOPWATCH CASIO J011Q03 S. 23 004 599 27-03-2023

### Inspection Method

0007/SOP\_BJS/2023  
 Procedure of Inspection Pneumatic and MOV

This certificate comprise of 1 page  
 Date of issue, 17-05-2024

Customer Signature,



Ayrton Humardani Putradhi

Approved Signatory,



M. Taufiq Nur Fitriyan

Calibrated by,



Daday Daryatun

Sertifikat ini berlaku untuk alat dengan nama, merek dan tipe / nomor seri yang dinyatakan diatas  
 This certificate applies only for the item specified above  
 Dilarang mengutip, memperbanyak dan / atau mempublikasikan isi sertifikat ini tanpa izin dari PT. Hervitama Indonesia  
 It is prohibited to copy, reproduce and / or publish the content of this Certificate without PT Hervitama Indonesia's approval  
 \*Sertifikat ini sah bila dibubuhi cap PT. Hervitama Indonesia dan ditandatangani oleh pejabat yang berwenang  
 This certificate is valid if it has approved and signed by authorized person

