

CERTIFICATE OF CALIBRATION PRESSURE TRANSMITTER

Certificate No. : 0375-24-HI-CAL-10C

Customer Information

Company Name PT. Bumi Jati Power
Address PLTU Tanjung Jati B Unit 5&6 Tubanan, Kembang, Jepara - Jawa Tengah
Contract No. C-BJP-24-0013-OTH

Instrument Information

KKS No.	60LBQ10CP005	Range	0 ~ 80
Instrument Description	HP HEATER 8 EXTRACTION STEAM PRESSURE	Unit	barg
Manufacture	YOKOGAWA	Out. Signal	4 - 20 mA
Model	EJX430A	Max. Error	0.5 %
Serial Number	91V703372	Cal. Date	13-05-2024
Instrument Location	TURBINE 2ND FLOOR		

Environment Condition

Temperature 30.9 °C
Humidity 63 % RH

Calibration Result

Data Reading (Transmitter)											
As Found						As Left					
Input	Std Output	Output UUT	Deviation	Error	Result	Input	Std Output	Output UUT	Deviation	Error	Result
[barg]	[mA]	[mA]		[%]		[barg]	[mA]	[mA]		[%]	
0.00	4.000	3.996	-0.004	-0.025	Pass						
20.06	8.000	7.995	-0.005	-0.031	Pass						
40.06	12.000	12.005	0.005	0.031	Pass						
60.05	16.000	15.985	-0.015	-0.094	Pass						
80.05	20.000	20.025	0.025	0.156	Pass						
80.05	20.000	20.025	0.025	0.156	Pass						
60.05	16.000	16.013	0.013	0.081	Pass						
40.06	12.000	12.012	0.012	0.075	Pass						
20.06	8.000	8.016	0.016	0.100	Pass						
0.00	4.000	4.004	0.004	0.025	Pass						

Standard Reference

Description	Serial Number	Certificate Number	Calibration Date
Documenting Process Calibrator Fluke 754	3611011	S. 22 011 747	23-09-2023
PRESSURE MODULE P31	4472839	S. 23 004 595	27-03-2023

Calibration Method

0001/SOP_BJS/2023
Procedure of Calibration Pressure & Differential Transmitter

This certificate comprise of 1 page
Date of issue, 14-05-2024

Customer Signature,



Ayrton Humardani Putradhi

Approved Signatory,



M. Taufiq Nur Filayan

Calibrated by,



Handi Suryawinata

Sertifikat ini berlaku untuk alat dengan nama, merek dan tipe / nomor seri yang dinyatakan diatas
This certificate applies only for the item specified above
Dilarang mengutip, memperbanyak dan / atau mempublikasikan isi sertifikat ini tanpa izin dari PT. Hervitama Indonesia
It is prohibited to copy, reproduce and / or publish the content of this Certificate without PT Hervitama Indonesia's approval
*Sertifikat ini sah bila dibubuhi cap PT. Hervitama Indonesia dan ditandatangani oleh pejabat yang berwenang
This certificate is valid if it has approved and signed by authorized person

