

## REPORT OF INSPECTION MOTORIZED OF VALVE

Certificate No. : 0889-24-HI-CAL-10J

### Customer Information

Company Name PT. Bhumi Jati Power  
Address PLTU Tanjung Jati B Unit 5&6 Tubanan, Kembang, Jepara - Jawa Tengah  
Contract No. C-BJP-24-0014-OTH

### Instrument Information

KKS No.	60LBQ11AA205	Power Supply	380 VAC
Instrument Description	HP HTR 8A EXTRSTM INL VALVE	Stroke	0-100 %
Manufacture	ROTORK	Inspection Date	20-05-2024
Model	1Q35F16A		
Serial Number	J251830701		
Instrument Location	TURBINE 4TH FLOOR		

### Environment Condition

Temperature 31 °C  
Humidity 44 % RH

### Traveling Time

Open to Close 76.78 s  
Close to Open 76.50 s

### Stroke Result

Command	Local	Stroke	DCS FB
[%]	[%]	[mm]	[%]

Command	Feedback			
	Local		DCS	
	Open	Close	Open	Close
Close	-	OK	-	OK
Open	OK	-	OK	-

### Visual Inspection

Leak Check	<input checked="" type="checkbox"/> OK	<input type="checkbox"/> Not OK	Tightness Check	<input checked="" type="checkbox"/> OK	<input type="checkbox"/> Not OK
Corrosion Condition	<input checked="" type="checkbox"/> OK	<input type="checkbox"/> Not OK	Accessories Check	<input checked="" type="checkbox"/> OK	<input type="checkbox"/> Not OK
Gearbox Condition	<input checked="" type="checkbox"/> OK	<input type="checkbox"/> Not OK			

### Remark

### Test Equipment

Description	Serial Number	Certificate Number	Calibration Date
Digital Multimeter Fluke 87V	16230349	S. 22 008 274	08-07-2022
STOPWATCH CASIO	J011Q03	S. 23 004 599	27-03-2023

### Inspection Method

0007/SOP\_BJS/2023  
Procedure of Inspection Pneumatic and MOV

This certificate comprise of 1 page  
Date of issue, 21-05-2024

Customer Signature,



Ayrton Humardani Putradhi

Approved Signature,



M. Taufiq Nur Fitriyan

Calibrated by,



Suryo Wicaksono

Sertifikat ini berlaku untuk alat dengan nama, merek dan tipe / nomor seri yang dinyatakan diatas  
This certificate applies only for the item specified above  
Dilarang mengutip, memperbanyak dan / atau mempublikasikan isi sertifikat ini tanpa izin dari PT. Hervitama Indonesia  
It is prohibited to copy, reproduce and / or publish the content of this Certificate without PT Hervitama Indonesia's approval  
\*Sertifikat ini sah bila dibubuhi cap PT. Hervitama Indonesia dan ditandatangani oleh pejabat yang berwenang  
This certificate is valid if it has approved and signed by authorized person

