

REPORT OF INSPECTION ON-OFF VALVE

Certificate No. : 1232-24-HI-CAL-10J

Customer Information

Company Name PT. Bhumi Jati Power
Address PLTU Tanjung Jati B Unit 5&6 Tubanan, Kembang, Jepara - Jawa Tengah
Contract No. C-BJP-24-0014-OTH

Instrument Information

KKS No. 60LBQ20AA820 Damping Time 1 s
Instrument Description HP HEATER 7 EXTRACTION NON RETURN VALVE Inspection Date 20-05-2024
OUTLET DRAIN VALVE
Manufacture NAKAKITA
Model NS650ELOL
Serial Number 16CY0638
Instrument Location TURBINE 3RD FLOOR

Environment Condition

Temperature 36 °C Traveling Time
Humidity 47 % RH Open to Close 01.35 s
Close to Open 01.55 s

Stroke Result

Command	Feedback			
	Local		DCS	
	Open	Close	Open	Close
Close	-	OK	-	OK
Open	OK	-	OK	-

Visual Inspection

Leak Check OK Not OK Tightness Check OK Not OK
Corrosion Condition OK Not OK Accessories Check OK Not OK

Remark

Test Equipment

Description STOPWATCH CASIO Serial Number J011Q03 Certificate Number S. 23 004 599 Calibration Date 27-03-2023

Inspection Method

0007/SOP_BJS/2023
Procedure of Inspection Pneumatic and MOV

This certificate comprise of 1 page
Date of issue, 21-05-2024


Customer Signature,



Ayrton Humardani Putradhi

Approved Signatory,

HERVITAMA



INDONESIA

Sertifikat ini berlaku untuk alat dengan nama, merek dan tipe / nomor seri yang dinyatakan diatas

This certificate applies only for the item specified above

Dilarang mengutip, memperbanyak dan / atau mempublikasikan isi sertifikat ini tanpa izin dari PT. Hervitama Indonesia

It is prohibited to copy, reproduce and / or publish the content of this Certificate without PT Hervitama Indonesia's approval

*Sertifikat ini sah bila dibubuhi cap PT. Hervitama Indonesia dan ditandatangani oleh pejabat yang berwenang

This certificate is valid if it has approved and signed by authorized person

Calibrated by,



Daday Daryatun

