

CERTIFICATE OF CALIBRATION PRESSURE TRANSMITTER

Certificate No. : 0376-24-HI-CAL-10C

Customer Information

Company Name: PT. Bhumi Jati Power
 Address: PLTU Tanjung Jati B Unit 5&6 Tubanan, Kembang, Jepara - Jawa Tengah
 Contract No.: C-BJP-24-0013-OTH

Instrument Information

KKS No.	60LBQ20CP005	Range	0 – 70
Instrument Description	HP HEATER 7 EXTRACTION STEAM PRESSURE	Unit	barg
Manufacture	YOKOGAWA	Out. Signal	4 - 20 mA
Model	EJX430A	Max. Error	0.5 %
Serial Number	91V703373	Cal. Date	12-05-2024
Instrument Location	TURBINE 3RD FLOOR		

Environment Condition

Temperature: 32.4 °C
 Humidity: 61 % RH

Calibration Result

Data Reading (Transmitter)											
As Found						As Left					
Input	Std Output	Output UUT	Deviation	Error	Result	Input	Std Output	Output UUT	Deviation	Error	Result
[barg]	[mA]	[mA]		[%]		[barg]	[mA]	[mA]		[%]	
0.000	4.000	3.980	-0.020	-0.125	Pass						
17.506	8.000	7.979	-0.021	-0.131	Pass						
35.005	12.000	11.977	-0.023	-0.144	Pass						
52.504	16.000	15.977	-0.023	-0.144	Pass						
70.002	20.000	19.980	-0.020	-0.125	Pass						
70.002	20.000	19.980	-0.020	-0.125	Pass						
52.504	16.000	15.977	-0.023	-0.144	Pass						
35.005	12.000	11.976	-0.024	-0.150	Pass						
17.506	8.000	7.978	-0.022	-0.138	Pass						
0.000	4.000	3.982	-0.018	-0.112	Pass						

Standard Reference

Description	Serial Number	Certificate Number	Calibration Date
Documenting Process Calibrator Fluke 754	3611011	S. 22 011 747	23-09-2023
Fluke Pressure Module 700P08	14070183	S. 23 004 594	27-03-2023

Calibration Method

0001/SOP_BJS/2023
 Procedure of Calibration Pressure & Differential Transmitter

This certificate comprise of 1 page
 Date of issue, 13-05-2024

Customer Signature,



Ayrtan Humardani Putradhi

Approved Signatory,



M. Taufiq Nur Fitriyan
 INDONESIA

Calibrated by,



Handi Suryawinata

Sertifikat ini berlaku untuk alat dengan nama, merek dan tipe / nomor seri yang dinyatakan diatas

This certificate applies only for the item specified above

Dilarang mengutip, memperbanyak dan / atau mempublikasikan isi sertifikat ini tanpa izin dari PT. Hervitama Indonesia

It is prohibited to copy, reproduce and / or publish the content of this Certificate without PT Hervitama Indonesia's approval

*Sertifikat ini sah bila dibubuhi cap PT. Hervitama Indonesia dan ditandatangani oleh pejabat yang berwenang

This certificate is valid if it has approved and signed by authorized person

