

## REPORT OF INSPECTION ON-OFF VALVE

Certificate No. : 1233-24-HI-CAL-10J

### Customer Information

Company Name PT. Bhumi Jati Power  
Address PLTU Tanjung Jati B Unit 5&6 Tubanan, Kembang, Jepara - Jawa Tengah  
Contract No. C-BJP-24-0014-OTH

### Instrument Information

KKS No. 60LBQ30AA205 Damping Time 0.5 s  
Instrument Description HP DSH EXTRACTION STEAM NON RETURN VALVE Inspection Date 20-05-2024  
Manufacture ASCO  
Model 322692  
Serial Number T546727  
Instrument Location TURBINE 2ND FLOOR

### Environment Condition

Temperature 32.6 °C  
Humidity 48 % RH

### Traveling Time

Open to Close 0.52 s  
Close to Open 0.54 s

### Stroke Result

| Command | Feedback |       |      |       |
|---------|----------|-------|------|-------|
|         | Local    |       | DCS  |       |
|         | Open     | Close | Open | Close |
| Close   | -        | OK    | -    | OK    |
| Open    | OK       | -     | OK   | -     |

### Visual Inspection

Leak Check  OK  Not OK Tightness Check  OK  Not OK  
Corrosion Condition  OK  Not OK Accessories Check  OK  Not OK

### Remark

### Test Equipment

| Description     | Serial Number | Certificate Number | Calibration Date |
|-----------------|---------------|--------------------|------------------|
| STOPWATCH CASIO | J011Q03       | S. 23 004 599      | 27-03-2023       |

### Inspection Method

0007/SOP\_BJS/2023  
Procedure of Inspection Pneumatic and MOV

This certificate comprise of 1 page  
Date of issue, 21-05-2024

Customer Signature,



Ayrtan Humardani Putradhi

HERVITAMA  
Approved Signatory,



M. Taufiq Nur Fitriyan  
INDONESIA

Calibrated by,



Daday Daryatun

Sertifikat ini berlaku untuk alat dengan nama, merek dan tipe / nomor seri yang dinyatakan diatas

*This certificate applies only for the item specified above*

Dilarang mengutip, memperbanyak dan / atau mempublikasikan isi sertifikat ini tanpa izin dari PT. Hervitama Indonesia

*It is prohibited to copy, reproduce and / or publish the content of this Certificate without PT Hervitama Indonesia's approval*

\*Sertifikat ini sah bila dibubuhi cap PT. Hervitama Indonesia dan ditandatangani oleh pejabat yang berwenang

*This certificate is valid if it has approved and signed by authorized person*

