

## CERTIFICATE OF CALIBRATION

### PRESSURE TRANSMITTER

Certificate No. : 0377-24-HI-CAL-10C

#### Customer Information

Company Name PT. Bhumi Jati Power  
 Address PLTU Tanjung Jati B Unit 5&6 Tubanan, Kembang, Jepara - Jawa Tengah  
 Contract No. C-BJP-24-0013-OTH

#### Instrument Information

KKS No.	60LBQ30CP005	Range	-1 ~ 30
Instrument Description	NO.6 EXTRACTION STEAM DESUPERHEATER STEAM PRESSURE	Unit	barg
Manufacture	YOKOGAWA	Out. Signal	4 - 20 mA
Model	EJX430A	Max. Error	0.5 %
Serial Number	91V703374	Cal. Date	13-05-2024
Instrument Location	TURBINE 3RD FLOOR		

#### Environment Condition

Temperature 30.9 °C  
 Humidity 63 % RH

#### Calibration Result

Data Reading (Transmitter)						Data Reading (Transmitter)					
As Found						As Left					
Input	Std Output	Output UUT	Deviation	Error	Result	Input	Std Output	Output UUT	Deviation	Error	Result
[barg]	[mA]	[mA]		[%]		[barg]	[mA]	[mA]		[%]	
-0.903	4.050	4.051	0.001	0.006	Pass						
6.750	8.000	8.000	0.000	0.000	Pass						
14.500	12.000	11.998	-0.002	-0.013	Pass						
22.256	16.000	16.008	0.008	0.050	Pass						
30.006	20.000	20.006	0.006	0.038	Pass						
30.006	20.000	20.006	0.006	0.038	Pass						
22.256	16.000	16.007	0.007	0.044	Pass						
14.550	12.000	11.999	-0.001	-0.006	Pass						
6.750	8.000	8.004	0.004	0.025	Pass						
-0.903	4.050	4.050	0.000	0.000	Pass						

#### Standard Reference

Description	Serial Number	Certificate Number	Calibration Date
Documenting Process Calibrator Fluke 754	3611011	S. 22 011 747	23-09-2023
Fluke Pressure Module 700P08	14070183	S. 23 004 594	27-03-2023

#### Calibration Method

0001/SOP\_BJS/2023  
 Procedure of Calibration Pressure & Differential Transmitter

This certificate comprise of 1 page  
 Date of issue, 14-05-2024

Customer Signature,



Ayrton Humardani Putradhi

Approved Signatory,



M. Taufiq Nur Fitriyan

Calibrated by,



Handi Suryawinala

Sertifikat ini berlaku untuk alat dengan nama, merek dan tipe / nomor seri yang dinyatakan diatas  
 This certificate applies only for the item specified above  
 Dilarang mengutip, memperbanyak dan / atau mempublikasikan isi sertifikat ini tanpa izin dari PT. Hervitama Indonesia  
 It is prohibited to copy, reproduce and / or publish the content of this Certificate without PT Hervitama Indonesia's approval  
 \*Sertifikat ini sah bila dibubuhi cap PT. Hervitama Indonesia dan ditandatangani oleh pejabat yang berwenang  
 This certificate is valid if it has approved and signed by authorized person

