

CERTIFICATE OF CALIBRATION
DIFFERENTIAL PRESSURE TRANSMITTER

Certificate No. : 0462-26-HI-CAL-10

Customer Information

Company Name PT. Bhumi Jati Power
Address PLTU Tanjung Jati B Unit 5&6 Tubanan, Kembang, Jepara - Jawa Tengah
Contract No. C-BJP-26-0004-OTH

Instrument Information

KKS No. 60LBQ30CP005
Instrument Description NO.6 EXTRACTION STEAM DESUPERHEATER STEAM PRESSURE
Manufacture YOKOGAWA
Model / Serial Number EJX430A / 91V703374
Instrument Location TURBINE 3RD FLOOR

Range -1 ~ 30
Unit bar g
Out. Signal 4 - 20 mA
Max. Error 0.5 %
Cal. Date 25-05-2026

Environment Condition

Temperature 30 °C Humidity 64 % RH

Calibration Result

Data Reading (Transmitter)											
As Found						As Left					
Input	Std Output	Output UUT	Deviation	Error	Result	Input	Std Output	Output UUT	Deviation	Error	Result
[bar g]	[mA]	[mA]		[%]		[bar g]	[mA]	[mA]		[%]	
-0.800	4.103	4.104	0.001	0.006	Pass						
6.750	8.000	8.000	0.000	0.000	Pass						
14.500	12.000	12.000	0.000	0.000	Pass						
22.249	15.999	16.003	0.004	0.025	Pass						
30.006	20.003	20.004	0.001	0.006	Pass						
22.249	15.999	16.000	0.001	0.006	Pass						
14.500	12.000	12.000	0.000	0.000	Pass						
6.750	8.000	8.002	0.002	0.013	Pass						
-0.800	4.013	4.000	-0.013	-0.081	Pass						

Visual Inspection (Checklist if OK)

Leak Check ☒ Tightness Check ☒ Corrosion Check ☒
Accessories Check ☒ Power Supply ☒

Standard Reference

Description	Serial Number	Certificate Number	Calibration Date
DOCUMENTING PROCESS CALIBRATOR FLUKE 754	56070038	MAL 26031230	06-03-2026
FLUKE PRESURE MODULE 700P08	14070813	MAL 26031235	03-03-2026

Calibration Method

0001/SOP_BJS/2025
Standard Operating Procedure of Calibration Pressure & Differential Transmitter

This certificate comprises 2 pages
Date of issue, 27-05-2026

Customer Signature,

Ayrton Humardani Putradhi

Approved Signatory

HERVITAMA

Ivan Hamid Shari

Calibrated by,

Akhmad Nashoikhuddin

Sertifikat ini berlaku untuk alat dengan nama, merek dan tipe / nomor seri yang dinyatakan diatas

This certificate applies only for the item specified above

Tidak dibenarkan mempublikasikan/memperbanyak sebagian isi sertifikat ini tanpa ijin PT. Hervitama Indonesia

This certificate shall not be produced/reproduced except in full without the written approval of PT. Hervitama Indonesia

*Sertifikat ini sah bila dibubuhi cap PT. Hervitama Indonesia dan ditandatangani oleh pejabat yang berwenang

This certificate is valid if it has approved and signed by authorized person