

CERTIFICATE OF CALIBRATION

PRESSURE TRANSMITTER

Certificate No. : 0378-24-HI-CAL-10C

Customer Information

Company Name PT. Bumi Jati Power
Address PLTU Tanjung Jati B Unit 5&6 Tubanan, Kembang, Jepara - Jawa Tengah
Contract No. C-BJP-24-0013-OTH

Instrument Information

KKS No.	60LBQ31CP005	Range	-0.891 ~ 15.109
Instrument Description	HP HEATER 6A EXTRACTION STEAM PRESSURE	Unit	barg
Manufacture	YOKOGAWA	Out. Signal	4 - 20 mA
Model	EJX430A	Max. Error	0.5 %
Serial Number	91V703375	Cal. Date	13-05-2024
Instrument Location	TURBINE 3RD FLOOR		

Environment Condition

Temperature 30.9 °C
Humidity 63 % RH

Calibration Result

Data Reading (Transmitter)											
As Found						As Left					
Input	Std Output	Output UUT	Deviation	Error	Result	Input	Std Output	Output UUT	Deviation	Error	Result
[barg]	[mA]	[mA]		[%]		[barg]	[mA]	[mA]		[%]	
-0.785	4.000	3.993	-0.007	-0.044	Pass						
6.964	8.000	7.989	-0.011	-0.069	Pass						
14.713	12.000	11.989	-0.011	-0.069	Pass						
22.463	16.000	15.984	-0.016	-0.100	Pass						
30.213	20.000	19.988	-0.012	-0.075	Pass						
30.213	20.000	19.988	-0.012	-0.075	Pass						
22.463	16.000	15.987	-0.013	-0.081	Pass						
14.713	12.000	11.995	-0.005	-0.031	Pass						
6.964	8.000	7.990	-0.010	-0.062	Pass						
-0.786	4.000	3.992	-0.008	-0.050	Pass						

Standard Reference

Description	Serial Number	Certificate Number	Calibration Date
Documenting Process Calibrator Fluke 754	3611011	S. 22 011 747	23-09-2023
Fluke Pressure Module 700P08	14070183	S. 23 004 594	27-03-2023

Calibration Method

0001/SOP_BJS/2023
Procedure of Calibration Pressure & Differential Transmitter

This certificate comprise of 1 page
Date of issue, 14-05-2024

Customer Signature,



Ayrton Humardani Putradhi

Approved Signatory,



M. Tawing Nur Fitriyan

Calibrated by,



Handi Suryawinata

Sertifikat ini berlaku untuk alat dengan nama, merek dan tipe / nomor seri yang dinyatakan diatas

This certificate applies only for the item specified above

Dilarang mengutip, memperbanyak dan / atau mempublikasikan isi sertifikat ini tanpa izin dari PT. Hervitama Indonesia

It is prohibited to copy, reproduce and / or publish the content of this Certificate without PT Hervitama Indonesia's approval

*Sertifikat ini sah bila dibubuhi cap PT. Hervitama Indonesia dan ditandatangani oleh pejabat yang berwenang

This certificate is valid if it has approved and signed by authorized person

