

CERTIFICATE OF CALIBRATION
DIFFERENTIAL PRESSURE TRANSMITTER

Certificate No. : 0463-26-HI-CAL-10

Customer Information

Company Name PT. Bhumi Jati Power
Address PLTU Tanjung Jati B Unit 5&6 Tubanan, Kembang, Jepara - Jawa Tengah
Contract No. C-BJP-26-0004-OTH

Instrument Information

KKS No. 60LBQ31CP005 Range -0.785 ~ 30.215
Instrument Description HP HEATER 6A EXTRACTION STEAM PRESSURE Unit bar g
Manufacture YOKOGAWA Out. Signal 4 - 20 mA
Model / Serial Number EJX430A / 91V703375 Max. Error 0.5 %
Instrument Location TURBINE 3RD FLOOR Cal. Date 24-05-2026

Environment Condition

Temperature 32 °C Humidity 65 % RH

Calibration Result

Data Reading (Transmitter)											
As Found						As Left					
Input	Std Output	Output UUT	Deviation	Error	Result	Input	Std Output	Output UUT	Deviation	Error	Result
[bar g]	[mA]	[mA]		[%]		[bar g]	[mA]	[mA]		[%]	
-0.786	3.999	3.999	0.000	0.000	Pass						
6.964	7.999	7.997	-0.002	-0.013	Pass						
14.713	11.998	12.000	0.002	0.013	Pass						
22.463	15.999	16.002	0.003	0.019	Pass						
30.213	19.998	20.001	0.003	0.019	Pass						
22.463	15.999	16.003	0.004	0.025	Pass						
14.713	11.998	12.003	0.005	0.031	Pass						
6.964	7.999	8.003	0.004	0.025	Pass						
-0.786	3.999	4.000	0.001	0.006	Pass						

Visual Inspection (Checklist if OK)

Leak Check ☒ Tightness Check ☒ Corrosion Check ☒
Accessories Check ☒ Power Supply ☒

Standard Reference

Description	Serial Number	Certificate Number	Calibration Date
DOCUMENTING PROCESS CALIBRATOR FLUKE 754	56070038	MAL 26031230	06-03-2026
FLUKE PRESURE MODULE 700P08	14070183	S. 25 003 021	05-03-2025

Calibration Method

0001/SOP_BJS/2025
Standard Operating Procedure of Calibration Pressure & Differential Transmitter

This certificate comprises 2 pages
Date of issue, 26-05-2026

Customer Signature,

Ayrton Humardani Putradhi

Approved Signatory,

HERVITAMA

INDONESIA

Ivan Hasan Ashari

Calibrated by,

Akhmad Nashoikhuddin

Sertifikat ini berlaku untuk alat dengan nama, merek dan tipe / nomor seri yang dinyatakan diatas

This certificate applies only for the item specified above

Tidak dibenarkan mempublikasikan/memperbanyak sebagian isi sertifikat ini tanpa ijin PT. Hervitama Indonesia

This certificate shall not be produced/reproduced except in full without the written approval of PT. Hervitama Indonesia

*Sertifikat ini sah bila dibubuhi cap PT. Hervitama Indonesia dan ditandatangani oleh pejabat yang berwenang

This certificate is valid if it has approved and signed by authorized person

