

REPORT OF INSPECTION MOTORIZED OF VALVE

Certificate No. : 0894-24-HI-CAL-10J

Customer Information

Company Name: PT. Bhumi Jati Power
 Address: PLTU Tanjung Jati B Unit 5&6 Tubanan, Kembang, Jepara - Jawa Tengah
 Contract No.: C-BJP-24-0014-OTH

Instrument Information

KKS No.: 60LBQ32AA205 Power Supply: 380 VAC
 Instrument Description: HP6 EXTRSTM DSH B EXTRSTM INLET VALVE Stroke: 525 mm
 Manufacture: ROTORK
 Model: 1Q35F16A Inspection Date: 15-05-2024
 Serial Number: NT38300201
 Instrument Location: TURBINE 3RD FLOOR

Environment Condition

Temperature: 32 °C Traveling Time
 Humidity: 41 % RH Open to Close: 39.66 s
Close to Open: 41.88 s

Stroke Result

Command	Local	Stroke	DCS FB
[%]	[%]	[mm]	[%]

Command	Feedback			
	Local		DCS	
	Open	Close	Open	Close
Close	-	OK	-	OK
Open	OK	-	OK	-

Visual Inspection

Leak Check: OK Not OK Tightness Check: OK Not OK
 Corrosion Condition: OK Not OK Accessories Check: OK Not OK
 Gearbox Condition: OK Not OK

Remark

Test Equipment

Description	Serial Number	Certificate Number	Calibration Date
Digital Multimeter Fluke 87V	16230349	S. 22 008 274	08-07-2022
STOPWATCH CASIO	J011Q03	S. 23 004 599	27-03-2023

Inspection Method

0007/SOP_BJS/2023
 Procedure of Inspection Pneumatic and MOV

This certificate comprise of 1 page
 Date of issue, 16-05-2024

Customer Signature,

Ayrton Humardani Putradhi

HERVITAMA
 Approved Signatory,

M. Taufiqul Fitriyan

Calibrated by,

Suryo Wicaksono

Sertifikat ini berlaku untuk alat dengan nama, merek dan tipe / nomor seri yang dinyatakan diatas
 This certificate applies only for the item specified above

Dilarang mengutip, memperbanyak dan / atau mempublikasikan isi sertifikat ini tanpa izin dari PT. Hervitama Indonesia
 It is prohibited to copy, reproduce and / or publish the content of this Certificate without PT Hervitama Indonesia's approval

*Sertifikat ini sah bila dibubuhi cap PT. Hervitama Indonesia dan ditandatangani oleh pejabat yang berwenang
 This certificate is valid if it has approved and signed by authorized person

