

## CERTIFICATE OF CALIBRATION

### PRESSURE TRANSMITTER

Certificate No. : 0379-24-HI-CAL-10C

#### Customer Information

Company Name PT. Bumi Jati Power  
 Address PLTU Tanjung Jati B Unit 5&6 Tubanan, Kembang, Jepara - Jawa Tengah  
 Contract No. C-BJP-24-0013-OTH

#### Instrument Information

KKS No.	60LBQ32CP005	Range	-0.891 ~ 15.109
Instrument Description	HP HEATER 6B EXTRACTION STEAM PRESSURE	Unit	barg
Manufacture	YOKOGAWA	Out. Signal	4 - 20 mA
Model	EJX430A	Max. Error	0.5 %
Serial Number	91V703376	Cal. Date	13-05-2024
Instrument Location	TURBINE 3RD FLOOR		

#### Environment Condition

Temperature 30.9 °C  
 Humidity 63 % RH

#### Calibration Result

Data Reading (Transmitter)											
As Found						As Left					
Input	Std Output	Output UUT	Deviation	Error	Result	Input	Std Output	Output UUT	Deviation	Error	Result
[barg]	[mA]	[mA]		[%]		[barg]	[mA]	[mA]		[%]	
-0.785	4.000	4.005	0.005	0.031	Pass						
6.964	8.000	7.999	-0.001	-0.006	Pass						
14.713	12.000	11.999	-0.001	-0.006	Pass						
22.463	16.000	16.000	0.000	0.000	Pass						
30.213	20.000	19.994	-0.006	-0.038	Pass						
30.213	20.000	19.994	-0.006	-0.038	Pass						
22.463	16.000	15.996	-0.004	-0.025	Pass						
14.713	12.000	11.997	-0.003	-0.019	Pass						
6.964	8.000	7.996	-0.004	-0.025	Pass						
-0.785	4.000	4.005	0.005	0.031	Pass						

#### Standard Reference

Description	Serial Number	Certificate Number	Calibration Date
Documenting Process Calibrator Fluke 754	3611011	S. 22 011 747	23-09-2023
Fluke Pressure Module 700P08	14070183	S. 23 004 594	27-03-2023

#### Calibration Method

0001/SOP\_BJS/2023  
 Procedure of Calibration Pressure & Differential Transmitter

This certificate comprise of 1 page  
 Date of issue, 14-05-2024

Customer Signature,



Ayrtan Humardani Putradhi

Approved Signatory,



M. Taufiq Nur Fitriyan

Calibrated by,



Handi Suryawinata

Sertifikat ini berlaku untuk alat dengan nama, merek dan tipe / nomor seri yang dinyatakan diatas  
 This certificate applies only for the item specified above  
 Dilarang mengutip, memperbanyak dan / atau mempublikasikan isi sertifikat ini tanpa izin dari PT. Hervitama Indonesia  
 It is prohibited to copy, reproduce and / or publish the content of this Certificate without PT Hervitama Indonesia's approval  
 \*Sertifikat ini sah bila dibubuhi cap PT. Hervitama Indonesia dan ditandatangani oleh pejabat yang berwenang  
 This certificate is valid if it has approved and signed by authorized person

