

CERTIFICATE OF CALIBRATION DIFFERENTIAL PRESSURE TRANSMITTER

Certificate No. : 0464-26-HI-CAL-10

Customer Information

Company Name PT. Bhumi Jati Power
Address PLTU Tanjung Jati B Unit 5&6 Tubanan, Kembang, Jepara - Jawa Tengah
Contract No. C-BJP-26-0004-OTH

Instrument Information

KKS No. 60LBQ32CP005

Instrument Description HP HEATER 6B EXTRACTION STEAM PRESSURE
Manufacture YOKOGAWA
Model / Serial Number EJX430A / 91V703376
Instrument Location TURBINE 3RD FLOOR

Range -0.785 ~ 30.215
Unit bar g
Out. Signal 4 - 20 mA
Max. Error 0.5 %
Cal. Date 24-05-2026

Environment Condition

Temperature 32 °C Humidity 65 % RH

Calibration Result

Data Reading (Transmitter)											
As Found						As Left					
Input	Std Output	Output UUT	Deviation	Error	Result	Input	Std Output	Output UUT	Deviation	Error	Result
[bar g]	[mA]	[mA]		[%]		[bar g]	[mA]	[mA]		[%]	
-0.786	3.999	3.998	-0.001	-0.006	Pass						
6.964	7.999	7.997	-0.002	-0.013	Pass						
14.713	11.998	11.995	-0.003	-0.019	Pass						
22.463	15.998	15.995	-0.003	-0.019	Pass						
30.213	19.998	19.991	-0.007	-0.044	Pass						
22.463	15.998	15.993	-0.005	-0.031	Pass						
14.713	11.998	11.995	-0.003	-0.019	Pass						
6.964	7.999	7.995	-0.004	-0.025	Pass						
-0.786	3.999	3.998	-0.001	-0.006	Pass						

Visual Inspection (Checklist if OK)

Leak Check ☒ Tightness Check ☒ Corrosion Check ☒
Accessories Check ☒ Power Supply ☒

Standard Reference

Description	Serial Number	Certificate Number	Calibration Date
DOCUMENTING PROCESS CALIBRATOR FLUKE 754	56070038	MAL 26031230	06-03-2026
FLUKE PRESURE MODULE 700P08	14070183	S. 25 003 021	05-03-2025

Calibration Method

0001/SOP_BJS/2025
Standard Operating Procedure of Calibration Pressure & Differential Transmitter

This certificate comprises 2 pages
Date of issue, 25-05-2026

Customer Signature,


Ayrton Humardani Putradhi

Approved Signatory,


HERVITAMA
INDONESIA
Iyan Hasan Ashari

Calibrated by,


Akhmad Nashoikhuddin

Sertifikat ini berlaku untuk alat dengan nama, merek dan tipe / nomor seri yang dinyatakan diatas

This certificate applies only for the item specified above

Tidak dibenarkan mempublikasikan/memperbanyak sebagian isi sertifikat ini tanpa ijin PT. Hervitama Indonesia

This certificate shall not be produced/reproduced except in full without the written approval of PT. Hervitama Indonesia

*Sertifikat ini sah bila dibubuhi cap PT. Hervitama Indonesia dan ditandatangani oleh pejabat yang berwenang

This certificate is valid if it has approved and signed by authorized person