

## REPORT OF INSPECTION ON-OFF VALVE Certificate No. : 1237-24-HI-CAL-10J

### Customer Information

Company Name PT. Bhumi Jati Power  
Address PLTU Tanjung Jati B Unit 5&6 Tubanan, Kembang, Jepara - Jawa Tengah  
Contract No. C-BJP-24-0014-OTH

### Instrument Information

KKS No. 60LBQ40AA215 Damping Time 1 s  
Instrument Description DEA AND FEED WATER TANK EXTRSTM NRV Inspection Date 20-05-2024  
Manufacture ASCO  
Model 322692  
Serial Number TS19419  
Instrument Location TURBINE 2ND FLOOR

### Environment Condition

Temperature 27.6 °C  
Humidity 42 % RH

### Traveling Time

Open to Close 01.71 s  
Close to Open 0.41 s

### Stroke Result

Command	Feedback			
	Local		DCS	
	Open	Close	Open	Close
Close	-	OK	-	OK
Open	OK	-	OK	-

### Visual Inspection

Leak Check  OK  Not OK Tightness Check  OK  Not OK  
Corrosion Condition  OK  Not OK Accessories Check  OK  Not OK

### Remark

### Test Equipment

Description	Serial Number	Certificate Number	Calibration Date
STOPWATCH CASIO	J011Q03	S. 23 004 599	27-03-2023

### Inspection Method

0007/SOP\_BJS/2023  
Procedure of Inspection Pneumatic and MOV

This certificate comprise of 1 page  
Date of issue, 21-05-2024

Customer Signature,

Ayrton Humardani Putradhi

Approved by,

M. Taufiq Nur Fitriyan  
INDONESIA

Calibrated by,

Dayad Daryatun

Sertifikat ini berlaku untuk alat dengan nama, merek dan tipe / nomor seri yang dinyatakan diatas

*This certificate applies only for the item specified above*

Dilarang mengutip, memperbanyak dan / atau mempublikasikan isi sertifikat ini tanpa izin dari PT. Hervitama Indonesia

*It is prohibited to copy, reproduce and / or publish the content of this Certificate without PT Hervitama Indonesia's approval*

*\*Sertifikat ini sah bila dibubuhi cap PT. Hervitama Indonesia dan ditandatangani oleh pejabat yang berwenang*

*This certificate is valid if it has approved and signed by authorized person*

