

CERTIFICATE OF CALIBRATION PRESSURE TRANSMITTER

Certificate No. : 0380-24-HI-CAL-10C

Customer Information

Company Name PT. Bhumi Jati Power
Address PLTU Tanjung Jati B Unit 5&6 Tubanan, Kembang, Jepara - Jawa Tengah
Contract No. C-BJP-24-0013-OTH

Instrument Information

KKS No.	60LBQ40CP005	Range	-0.891 ~ 15.109
Instrument Description	DEAERATOR EXTRACTION STEAM PRESSURE	Unit	barg
Manufacture	YOKOGAWA	Out. Signal	4 - 20 mA
Model	EJX430A	Max. Error	0.5 %
Serial Number	91V703377	Cal. Date	13-05-2024
Instrument Location	TURBINE 4TH FLOOR		

Environment Condition

Temperature 30.9 °C
Humidity 63 % RH

Calibration Result

Data Reading (Transmitter)											
As Found						As Left					
Input	Std Output	Output UUT	Deviation	Error	Result	Input	Std Output	Output UUT	Deviation	Error	Result
[barg]	[mA]	[mA]		[%]		[barg]	[mA]	[mA]		[%]	
-0.855	4.036	4.032	-0.004	-0.025	Pass						
3.110	8.000	7.977	-0.023	-0.144	Pass						
7.108	12.000	11.979	-0.021	-0.131	Pass						
11.107	16.000	15.970	-0.030	-0.187	Pass						
15.106	20.000	19.958	-0.042	-0.263	Pass						
15.106	20.000	19.958	-0.042	-0.263	Pass						
11.107	16.000	16.001	0.001	0.006	Pass						
7.108	12.000	11.995	-0.005	-0.031	Pass						
3.110	8.000	7.987	-0.013	-0.081	Pass						
-0.855	4.036	4.018	-0.018	-0.112	Pass						

Standard Reference

Description	Serial Number	Certificate Number	Calibration Date
Documenting Process Calibrator Fluke 754	3611011	S. 22 011 747	23-09-2023
Fluke Pressure Module 700P08	14070183	S. 23 004 594	27-03-2023

Calibration Method

0001/SOP_BJS/2023
Procedure of Calibration Pressure & Differential Transmitter

This certificate comprise of 1 page
Date of issue, 14-05-2024

Customer Signature,



Ayrton Humardani Putradhi

Approved Signatory,



M. Taufiq Nur Fauzan
INDONESIA

Calibrated by,



Handi Suryawinata

Sertifikat ini berlaku untuk alat dengan nama, merek dan tipe / nomor seri yang dinyatakan diatas
This certificate applies only for the item specified above

Dilarang mengutip, memperbanyak dan / atau mempublikasikan isi sertifikat ini tanpa izin dari PT. Hervitama Indonesia
It is prohibited to copy, reproduce and / or publish the content of this Certificate without PT. Hervitama Indonesia's approval

*Sertifikat ini sah bila dibubuhi cap PT. Hervitama Indonesia dan ditandatangani oleh pejabat yang berwenang

This certificate is valid if it has approved and signed by authorized person

