

CERTIFICATE OF CALIBRATION PRESSURE TRANSMITTER

Certificate No. : 0381-24-HI-CAL-10C

Customer Information

Company Name PT. Bhumi Jati Power
Address PLTU Tanjung Jati B Unit 5&6 Tubanan, Kembang, Jepara - Jawa Tengah
Contract No. C-BJP-24-0013-OTH

Instrument Information

KKS No.	60LBR10CP005	Range	0 ~ 15
Instrument Description	BFPT INLET STEAM HEADER PRESSURE	Unit	barg
Manufacture	YOKOGAWA	Out. Signal	4 - 20 mA
Model	EJX430A	Max. Error	0.5 %
Serial Number	91V703378	Cal. Date	10-05-2024
Instrument Location	TURBINE 2ND FLOOR		

Environment Condition

Temperature 31.7 °C
Humidity 66 % RH

Calibration Result

Data Reading (Transmitter)											
As Found						As Left					
Input	Std Output	Output UUT	Deviation	Error	Result	Input	Std Output	Output UUT	Deviation	Error	Result
[barg]	[mA]	[mA]		[%]		[barg]	[mA]	[mA]		[%]	
-0.903	4.096	4.078	-0.018	-0.112	Pass						
3.006	8.000	7.996	-0.004	-0.025	Pass						
7.005	12.000	11.993	-0.007	-0.044	Pass						
11.004	16.000	15.992	-0.008	-0.050	Pass						
15.003	20.000	19.998	-0.002	-0.013	Pass						
15.003	20.000	19.998	-0.002	-0.013	Pass						
11.004	16.000	15.994	-0.006	-0.037	Pass						
7.005	12.000	12.006	0.006	0.037	Pass						
3.006	8.000	7.998	-0.002	-0.013	Pass						
-0.903	4.096	4.085	-0.011	-0.069	Pass						

Standard Reference

Description	Serial Number	Certificate Number	Calibration Date
Documenting Process Calibrator Fluke 754	3611011	S. 22 011 747	23-09-2023
Fluke Pressure Module 700P08	14070183	S. 23 004 594	27-03-2023

Calibration Method

0001/SOP_BJS/2023
Procedure of Calibration Pressure & Differential Transmitter

This certificate comprise of 1 page

Date of issue, 11-05-2024

Customer Signature,



Ayrton Humardani Putradhi

Approved By,



M. Taufiq Nur Fitriyan

INDONESIA

Calibrated by,



Fandi Suryawinata

Sertifikat ini berlaku untuk alat dengan nama, merek dan tipe / nomor seri yang dinyatakan diatas
This certificate applies only for the item specified above
Dilarang mengutip, memperbanyak dan / atau mempublikasikan isi sertifikat ini tanpa izin dari PT. Hervitama Indonesia
It is prohibited to copy, reproduce and / or publish the content of this Certificate without PT Hervitama Indonesia's approval
*Sertifikat ini sah bila dibubuhi cap PT. Hervitama Indonesia dan ditandatangani oleh pejabat yang berwenang
This certificate is valid if it has approved and signed by authorized person

