

CERTIFICATE OF CALIBRATION DIFFERENTIAL PRESSURE TRANSMITTER

Certificate No. : 0466-26-HI-CAL-10

Customer Information

Company Name PT. Bhumi Jati Power
Address PLTU Tanjung Jati B Unit 5&6 Tubanan, Kembang, Jepara - Jawa Tengah
Contract No. C-BJP-26-0004-OTH

Instrument Information

KKS No. 60LBR10CP005
Instrument Description BFPT INLET STEAM HEADER PRESSURE
Manufacture YOKOGAWA
Model / Serial Number EJX430A / 91V703378
Instrument Location TURBINE 2ND FLOOR

Range 0 ~ 15
Unit bar g
Out. Signal 4 - 20 mA
Max. Error 0.5 %
Cal. Date 25-05-2026

Environment Condition

Temperature 30 °C Humidity 64 % RH

Calibration Result

Data Reading (Transmitter)											
As Found						As Left					
Input	Std Output	Output UUT	Deviation	Error	Result	Input	Std Output	Output UUT	Deviation	Error	Result
[bar g]	[mA]	[mA]		[%]		[bar g]	[mA]	[mA]		[%]	
-0.800	4.200	4.209	0.009	0.056	Pass						
3.006	8.006	8.015	0.009	0.056	Pass						
6.998	11.998	12.011	0.013	0.081	Pass						
11.004	16.003	16.014	0.011	0.069	Pass						
15.003	20.003	20.006	0.003	0.019	Pass						
11.004	16.003	16.010	0.007	0.044	Pass						
7.005	12.005	12.013	0.008	0.050	Pass						
3.006	8.006	8.012	0.006	0.038	Pass						
-0.800	4.200	4.203	0.003	0.019	Pass						

Visual Inspection (Checklist if OK)

Leak Check ☒ Tightness Check ☒ Corrosion Check ☒
Accessories Check ☒ Power Supply ☒

Standard Reference

Description	Serial Number	Certificate Number	Calibration Date
DOCUMENTING PROCESS CALIBRATOR FLUKE 754	56070038	MAL 26031230	06-03-2026
FLUKE PRESURE MODULE 700P08	14070813	MAL 26031235	03-03-2026

Calibration Method

0001/SOP_BJS/2025
Standard Operating Procedure of Calibration Pressure & Differential Transmitter

This certificate comprises 2 pages
Date of issue, 27-05-2026

Customer Signature,


Ayron Humardani Putradhi

Approved Signatory,


Ivan Hasan Ashari
INDONESIA

Calibrated by,


Akhmad Nashoikhuddin

Sertifikat ini berlaku untuk alat dengan nama, merek dan tipe / nomor seri yang dinyatakan diatas

This certificate applies only for the item specified above

Tidak dibenarkan mempublikasikan/memperbanyak sebagian isi sertifikat ini tanpa ijin PT. Hervitama Indonesia

This certificate shall not be produced/reproduced except in full without the written approval of PT. Hervitama Indonesia

*Sertifikat ini sah bila dibubuhi cap PT. Hervitama Indonesia dan ditandatangani oleh pejabat yang berwenang

This certificate is valid if it has approved and signed by authorized person