

CERTIFICATE OF CALIBRATION DIFFERENTIAL PRESSURE TRANSMITTER

Certificate No. : 0382-24-HI-CAL-10C

Customer Information

Company Name: PT. Bumi Jati Power
 Address: PLTU Tanjung Jati B Unit 5&6 Tubanan, Kembang, Jepara - Jawa Tengah
 Contract No.: C-BJP-24-0013-OTH

Instrument Information

KKS No.	60LBR11CF010	Range	0 ~ 200
Instrument Description	BFPT A INLET STEAM FLOW	Unit	mbar
Manufacture	YOKOGAWA	Out. Signal	4 - 20 mA
Model	EJX110A	Max. Error	0.5 %
Serial Number	91V703360	Cal. Date	10-05-2024
Instrument Location	TURBINE 1ST FLOOR		

Environment Condition

Temperature: 28.3 °C
 Humidity: 51 % RH

Calibration Result

As Found						Data Reading (Transmitter)					As Left						
Input	Std Output	Output UUT	Deviation	Error	Result	Input	Std Output	Output UUT	Deviation	Error	Result	Input	Std Output	Output UUT	Deviation	Error	Result
[mbar]	[mA]	[mA]		[%]		[mbar]	[mA]	[mA]		[%]		[mbar]	[mA]	[mA]		[%]	
0	4.000	4.001	0.001	0.006	Pass												
50	8.000	8.000	0.000	0.000	Pass												
100	12.000	12.004	0.004	0.025	Pass												
150	16.000	16.001	0.001	0.006	Pass												
200	20.000	20.005	0.005	0.031	Pass												
200	20.000	20.005	0.005	0.031	Pass												
150	16.000	15.999	-0.001	-0.006	Pass												
100	12.000	11.995	-0.005	-0.031	Pass												
50	8.000	7.997	-0.003	-0.019	Pass												
0	4.000	4.001	0.001	0.006	Pass												

Standard Reference

Description	Serial Number	Certificate Number	Calibration Date
Documenting Process Calibrator Fluke 754	56070038	S. 22 002 081	17-02-2022
Pressure Module Fluke 750PD4	4474073	S. 23 014 461	10-10-2023

Calibration Method

0001/SOP_BJS/2023
 Procedure of Calibration Pressure & Differential Transmitter

This certificate comprise of 1 page
 Date of issue, 11-05-2024

Customer Signature,




Ayrtan Humardani Putradhi

HERVITAMA
 Approved Signatory,



M. Taufiq Nur Fitriyan

Calibrated by,



Faisol Anwar

Sertifikat ini berlaku untuk alat dengan nama, merek dan tipe / nomor seri yang dinyatakan diatas
 This certificate applies only for the item specified above
 Dilarang mengutip, memperbanyak dan / atau mempublikasikan isi sertifikat ini tanpa izin dari PT. Hervitama Indonesia
 It is prohibited to copy, reproduce and / or publish the content of this Certificate without PT Hervitama Indonesia's approval
 *Sertifikat ini sah bila dibubuhi cap PT. Hervitama Indonesia dan ditandatangani oleh pejabat yang berwenang
 This certificate is valid if it has approved and signed by authorized person

