

CERTIFICATE OF CALIBRATION

PRESSURE SWITCH

Certificate No. : 0516-24-HI-CAL-10B

Customer Information

Company Name PT. Bhumi Jati Power
Address PLTU Tanjung Jati B Unit 5&6 Tubanan, Kembang, Jepara - Jawa Tengah
Contract No. C-BJP-24-0013-OTH

Instrument Information

KKS No.	60LBR11CP305	Range	-1 - 0
Instrument Description	BFPT A EXHAUST STEAM PRESSURE HIGH	Set	-0.831
Manufacture	NAGANO KEIKI	Reset	-0.858
Model	CB33	Unit	barg
Serial Number	W12883	MPE	± 0.005
Instrument Location	TURBINE 2ND FLOOR	Cal. Date	10-05-2024

Environment Condition

Temperature 32.7 °C
Humidity 66 % RH

Calibration Result

Data Reading (Switch)					
As Found			As Left		
Set	Reset	Deadband	Set	Reset	Deadband
-0.832	-0.850	0.018			
-0.832	-0.850	0.018			
-0.832	-0.850	0.018			

Standard Reference

Description	Serial Number	Certificate Number	Calibration Date
Documenting Process Calibrator Fluke 754	3611011	S. 22 011 747	23-09-2023
Fluke Pressure Module 750PD27	6087359	S. 23 014 459	09-10-2023

Calibration Method

0003/SOP_BJS/2023
Procedure of Calibration Pressure Switch

This certificate comprise of 1 page
Date of issue, 11-05-2024

Customer Signature,



Ayrton Humardani Putradhi

Approved Signatory,



MINDONESIA Ariyan

Calibrated by,



Handi Suryawinata

Sertifikat ini berlaku untuk alat dengan nama, merek dan tipe / nomor seri yang dinyatakan diatas

This certificate applies only for the item specified above

Dilarang mengutip, memperbanyak dan / atau mempublikasikan isi sertifikat ini tanpa izin dari PT. Hervitama Indonesia

It is prohibited to copy, reproduce and / or publish the content of this Certificate without PT Hervitama Indonesia's approval

*Sertifikat ini sah bila dibubuhi cap PT. Hervitama Indonesia dan ditandatangani oleh pejabat yang berwenang

This certificate is valid if it has approved and signed by authorized person

