

CERTIFICATE OF CALIBRATION
PRESSURE SWITCH

Certificate No. : 0074-26-HI-CAL-10

Customer Information

Company Name PT. Bhumi Jati Power
Address PLTU Tanjung Jati B Unit 5&6 Tubanan, Kembang, Jepara - Jawa Tengah
Contract No. C-BJP-26-0004-OTH

Instrument Information

KKS No. 60LBR11CP305
Instrument Description BFPT A EXHAUST STEAM PRESSURE HIGH
Manufacture NAGANO KEIKI
Model / Serial Number CB33 / W12883
Instrument Location TURBINE 2ND FLOOR

Range -1 - 0
Set -0.831
Reset -0.858
Unit bar g
MPE ± 0.005
Cal. Date 06-06-2026

Environment Condition

Temperature 31 °C Humidity 74 % RH

Calibration Result

Data Reading (Switch)					
As Found			As Left		
Set	Reset	Deadband	Set	Reset	Deadband
-0.827	-0.851	0.024			
-0.827	-0.851	0.024			
-0.827	-0.851	0.024			

Visual Inspection (Checklist if OK)

Leak Check ☒ Tightness Check ☒ Corrosion Check ☒
Accessories Check ☒ Power Supply ☒

Standard Reference

Description	Serial Number	Certificate Number	Calibration Date
DOCUMENTING PROCESS	2448033	4482/25/EX/10/2025	26-09-2025
CALIBRATOR FLUKE 754			
FLUKE PRESURE MODULE 750PD6	6094437	02170/GQI-Sert/03/26	09-03-2026

Calibration Method

0003/SOP_BJS/2025
Standard Operating Procedure of Calibration Pressure Switch

This certificate comprises 2 pages
Date of issue, 10-06-2026

Customer Signature,

Ayrton Humardani Putradhi

Approved Signatory,

INDONESIA

Ivan Hasan Ashari

Calibrated by,

Ryan Franki Risdianto

Sertifikat ini berlaku untuk alat dengan nama, merek dan tipe / nomor seri yang dinyatakan diatas

This certificate applies only for the item specified above

Tidak dibenarkan mempublikasikan/memperbanyak sebagian isi sertifikat ini tanpa ijin PT. Hervitama Indonesia

This certificate shall not be produced/reproduced except in full without the written approval of PT. Hervitama Indonesia

*Sertifikat ini sah bila dibubuhi cap PT. Hervitama Indonesia dan ditandatangani oleh pejabat yang berwenang

This certificate is valid if it has approved and signed by authorized person