

## REPORT OF INSPECTION MOTORIZED OF VALVE

Certificate No. : 0899-24-HI-CAL-10J

### Customer Information

Company Name PT. Bhumi Jati Power  
Address PLTU Tanjung Jati B Unit 5&6 Tubanan, Kembang, Jepara - Jawa Tengah  
Contract No. C-BJP-24-0014-OTH

### Instrument Information

KKS No. 60LBR12AA205 Power Supply 380 VAC  
Instrument Description BFPT B MSV INLET VALVE Stroke 525 mm  
Manufacture ROTORK  
Model 1Q35F16A Inspection Date 21-05-2024  
Serial Number NT38300701  
Instrument Location TURBINE 2ND FLOOR

### Environment Condition

Temperature 30.1 °C  
Humidity 45 % RH

### Traveling Time

Open to Close 96.63 s  
Close to Open 96.50 s

### Stroke Result

Command	Local	Stroke	DCS FB
[%]	[%]	[mm]	[%]

Command	Feedback			
	Local		DCS	
	Open	Close	Open	Close
Close	-	OK	-	OK
Open	OK	-	OK	-

### Visual Inspection

Leak Check  OK  Not OK Tightness Check  OK  Not OK  
Corrosion Condition  OK  Not OK Accessories Check  OK  Not OK  
Gearbox Condition  OK  Not OK

### Remark

### Test Equipment


Description	Serial Number	Certificate Number	Calibration Date
Digital Multimeter Fluke 87V	16230349	S. 22 008 274	08-07-2022
STOPWATCH CASIO	J011Q03	S. 23 004 599	27-03-2023

### Inspection Method

0007/SOP\_BJS/2023  
Procedure of Inspection Pneumatic and MOV

This certificate comprise of 1 page  
Date of issue, 22-05-2024

Customer Signature,



Ayrton Humardani Putradhi

Approved Signatory,



M. Fauziq Nur Filrivan

Calibrated by,



Suryo Wicaksono

Sertifikat ini berlaku untuk alat dengan nama, merek dan tipe / nomor seri yang dinyatakan diatas

*This certificate applies only for the item specified above*

Dilarang mengutip, memperbanyak dan / atau mempublikasikan isi sertifikat ini tanpa izin dari PT. Hervitama Indonesia

*It is prohibited to copy, reproduce and / or publish the content of this Certificate without PT Hervitama Indonesia's approval*

\*Sertifikat ini sah bila dibubuhi cap PT. Hervitama Indonesia dan ditandatangani oleh pejabat yang berwenang

*This certificate is valid if it has approved and signed by authorized person*

