

## CERTIFICATE OF CALIBRATION DIFFERENTIAL PRESSURE TRANSMITTER

Certificate No. : 0383-24-HI-CAL-10C

### Customer Information

Company Name PT. Bhumi Jati Power  
 Address PLTU Tanjung Jati B Unit 5&6 Tubanan, Kembang, Jepara - Jawa Tengah  
 Contract No. C-BJP-24-0013-OTH

### Instrument Information

KKS No.	60LBR12CF010	Range	0 ~ 200
Instrument Description	BFPT B INLET STEAM FLOW	Unit	mbar
Manufacture	YOKOGAWA	Out. Signal	4 - 20 mA
Model	EJX110A	Max. Error	0.5 %
Serial Number	91V703361	Cal. Date	10-05-2024
Instrument Location	TURBINE 1ST FLOOR		

### Environment Condition

Temperature 28.2 °C  
 Humidity 52 % RH

### Calibration Result

Data Reading (Transmitter)					
As Found			As Left		
Input	Std Output	Output UUT	Deviation	Error	Result
[mbar]	[mA]	[mA]		[%]	
0	4.000	4.005	0.005	0.031	Pass
50	8.000	7.993	-0.007	-0.044	Pass
100	12.000	11.987	-0.013	-0.081	Pass
150	16.000	15.992	-0.008	-0.050	Pass
200	20.000	19.992	-0.008	-0.050	Pass
200	20.000	19.992	-0.008	-0.050	Pass
150	16.000	15.991	-0.009	-0.056	Pass
100	12.000	11.991	-0.009	-0.056	Pass
50	8.000	7.993	-0.007	-0.044	Pass
0	4.000	4.005	0.005	0.031	Pass

### Standard Reference

Description	Serial Number	Certificate Number	Calibration Date
Documenting Process Calibrator Fluke 754	56070038	S. 22 002 081	17-02-2022
Pressure Module Fluke 750PD4	4474073	S. 23 014 461	10-10-2023

### Calibration Method

0001/SOP\_BJS/2023  
 Procedure of Calibration Pressure & Differential Transmitter

This certificate comprise of 1 page  
 Date of issue, 11-05-2024

Customer Signature,



Ayrton Humardani Putradhi

Approved Signatory,



M. Taufiq Nur Fitriyan

INDONESIA

Calibrated by,



Faishol Anwar

Sertifikat ini berlaku untuk alat dengan nama, merek dan tipe / nomor seri yang dinyatakan diatas

*This certificate applies only for the item specified above*

Dilarang mengutip, memperbanyak dan / atau mempublikasikan isi sertifikat ini tanpa izin dari PT. Hervitama Indonesia

*It is prohibited to copy, reproduce and / or publish the content of this Certificate without PT Hervitama Indonesia's approval*

\*Sertifikat ini sah bila dibubuhi cap PT. Hervitama Indonesia dan ditandatangani oleh pejabat yang berwenang

*This certificate is valid if it has approved and signed by authorized person*

