

## REPORT OF INSPECTION ON-OFF VALVE

Certificate No. : 1243-24-HI-CAL-10J

### Customer Information

Company Name PT. Bhumi Jati Power  
 Address PLTU Tanjung Jati B Unit 5&6 Tubanan, Kembang, Jepara - Jawa Tengah  
 Contract No. C-BJP-24-0014-OTH

### Instrument Information

KKS No. 60LBS10AA805 Damping Time 0.03 s  
 Instrument Description LP HEATER 4 EXTRACTION NON RETURN VALVE INLET DRAIN VALVE Inspection Date 16-05-2024  
 Manufacture NAKAKITA  
 Model NS650  
 Serial Number 18CY0698  
 Instrument Location TURBINE 2ND FLOOR

### Environment Condition

Temperature 31 °C Traveling Time  
 Open to Close 00.77 s  
 Humidity 44 % RH Close to Open 00.17 s

### Stroke Result

Command	Feedback			
	Local		DCS	
	Open	Close	Open	Close
Close	-	OK	-	OK
Open	OK	-	OK	-

### Visual Inspection

Leak Check  OK  Not OK Tightness Check  OK  Not OK  
 Corrosion Condition  OK  Not OK Accessories Check  OK  Not OK  
 Air Regulator Check  OK  Not OK

### Remark

### Test Equipment

Description	Serial Number	Certificate Number	Calibration Date
STOPWATCH CASIO	J011Q03	S. 23 004 599	27-03-2023

### Inspection Method

0007/SOP\_BJS/2023  
 Procedure of Inspection Pneumatic and MOV


This certificate comprise of 1 page  
 Date of issue, 17-05-2024

Customer Signature,



Ayrtan Humardani Putradhi

Approved Signatory,



M. Tajid Nur Fitriyan

Calibrated by,



Daday Daryatun

Sertifikat ini berlaku untuk alat dengan nama, merek dan tipe / nomor seri yang dinyatakan diatas  
 This certificate applies only for the item specified above

Dilarang mengutip, memperbanyak dan / atau mempublikasikan isi sertifikat ini tanpa izin dari PT. Hervitama Indonesia  
 It is prohibited to copy, reproduce and / or publish the content of this Certificate without PT Hervitama Indonesia's approval

\*Sertifikat ini sah bila dibubuhi cap PT. Hervitama Indonesia dan ditandatangani oleh pejabat yang berwenang  
 This certificate is valid if it has approved and signed by authorized person

