

CERTIFICATE OF CALIBRATION DIFFERENTIAL PRESSURE TRANSMITTER

Certificate No. : 0469-26-HI-CAL-10

Customer Information

Company Name PT. Bhumi Jati Power
Address PLTU Tanjung Jati B Unit 5&6 Tubanan, Kembang, Jepara - Jawa Tengah
Contract No. C-BJP-26-0004-OTH

Instrument Information

KKS No. 60LBS10CP005
Instrument Description LP HEATER 4 EXTRACTION STEAM PRESSURE
Manufacture YOKOGAWA
Model / Serial Number EJX430A / 91V703379
Instrument Location TURBINE 3RD FLOOR

Range 0.734 ~ 4.266
Unit bar g
Out. Signal 4 - 20 mA
Max. Error 0.5 %
Cal. Date 31-05-2026

Environment Condition

Temperature 32 °C Humidity 70 % RH

Calibration Result

As Found						Data Reading (Transmitter)						As Left					
Input	Std Output	Output UUT	Deviation	Error	Result	Input	Std Output	Output UUT	Deviation	Error	Result	Input	Std Output	Output UUT	Deviation	Error	Result
[bar g]	[mA]	[mA]		[%]		[bar g]	[mA]	[mA]		[%]		[bar g]	[mA]	[mA]		[%]	
0.734	4.000	3.991	-0.009	-0.056	Pass												
0.516	8.000	7.983	-0.017	-0.106	Pass												
1.766	12.000	11.983	-0.017	-0.106	Pass												
3.016	16.000	15.985	-0.015	-0.094	Pass												
4.266	20.000	19.986	-0.014	-0.088	Pass												
3.016	16.000	15.991	-0.009	-0.056	Pass												
1.766	12.000	11.993	-0.007	-0.044	Pass												
0.516	8.000	7.996	-0.004	-0.025	Pass												
-0.734	4.000	4.004	0.004	0.025	Pass												

Visual Inspection (Checklist if OK)

Leak Check ☒ Tightness Check ☒ Corrosion Check ☒
Accessories Check ☒ Power Supply ☒

Standard Reference

Description	Serial Number	Certificate Number	Calibration Date
DOCUMENTING PROCESS CALIBRATOR FLUKE 754	56070038	MAL 26031230	06-03-2026
PRESSURE MODULE FLK 750PD27	6087359	02172/GQI-Sert/03/26	09-03-2026

Calibration Method

0001/SOP_BJS/2025
Standard Operating Procedure of Calibration Pressure & Differential Transmitter

This certificate comprises 2 pages
Date of issue, 04-06-2026

Customer Signature,

Ayrtan Humardani Putradhi

Approved Signatory,

Ivan Hasan Ashari

Calibrated by,

Akhmad Nasholkhuiddin

Sertifikat ini berlaku untuk alat dengan nama, merek dan tipe / nomor seri yang dinyatakan diatas

This certificate applies only for the item specified above

Tidak dibenarkan mempublikasikan/memperbanyak sebagian isi sertifikat ini tanpa ijin PT. Hervitama Indonesia

This certificate shall not be produced/reproduced except in full without the written approval of PT. Hervitama Indonesia

*Sertifikat ini sah bila dibubuhi cap PT. Hervitama Indonesia dan ditandatangani oleh pejabat yang berwenang

This certificate is valid if it has approved and signed by authorized person