

CERTIFICATE OF CALIBRATION
TEMPERATURE SENSOR

Certificate No. : 0876-26-HI-CAL-10

Customer Information

Company Name

PT. Bhumi Jati Power

Address

PLTU Tanjung Jati B Unit 5&6 Tubanan, Kembang, Jepara - Jawa Tengah

Contract No.

C-BJP-26-0004-OTH

Instrument Information

KKS No.

60LBS10CT005

Instrument Description

LP HEATER 4 EXTRACTION STEAM TEMPERATURE

Manufacture

YAMARI

Model / Serial Number

- / 5346958

Instrument Location

TURBINE 3RD FLOOR

Range

0 ~ 350

Unit

°C

Out. Signal

4 - 20 mA

Max. Deviation

3.5 °C

Cal. Date

13-06-2026

Temp. Element

Thermocouple Type E

Environment Condition

Temperature

29,4 °C

Humidity

53 % RH

Calibration Result

As Found					As Left				
Input	Std Output	Output UUT	Deviation	Result	Input	Std Output	Output UUT	Deviation	Result
[°C]	[°C]	[°C]			[°C]	[°C]	[°C]		
40	39.700	40.000	0.300	Pass					
87.5	87.900	88.300	0.400	Pass					
175	176.100	177.200	1.100	Pass					
262.5	263.300	264.900	1.600	Pass					
350	351.700	353.200	1.500	Pass					

Visual Inspection (Checklist if OK)

Leak Check



Tightness Check



Corrosion Check



Accessories Check



Power Supply



Standard Reference

Description

Serial Number

Certificate Number

Calibration Date

Temperature Calibrator Fluke 725

2815000

2256/25/KAL/06/2025

23-06-2025

DRY WELL CALIBRATOR ADDITEL

660TH210A0009

S-25010821

21-08-2025

875

Calibration Method

0002/SOP_BJS/2025

Standard Operating Procedure of Calibration Temperature Element, Temperature Transmitter & Temperature Switch

This certificate comprises 2 pages

Date of issue, 14-06-2026

Customer Signature,

Ayrton Humardani Putradhi

HERVITAMA

INDONESIA
Ivan Hasan Ashari

Calibrated by,

Khabib Mundzirul Umam

Sertifikat ini berlaku untuk alat dengan nama, merek dan tipe / nomor seri yang dinyatakan diatas

This certificate applies only for the item specified above

Tidak dibenarkan mempublikasikan/memperbanyak sebagian isi sertifikat ini tanpa ijin PT. Hervitama Indonesia

This certificate shall not be produced/reproduced except in full without the written approval of PT. Hervitama Indonesia

*Sertifikat ini sah bila dibubuhi cap PT. Hervitama Indonesia dan ditandatangani oleh pejabat yang berwenang

This certificate is valid if it has approved and signed by authorized person

