

REPORT OF INSPECTION MOTORIZED OF VALVE Certificate No. : 0903-24-HI-CAL-10J

Customer Information

Company Name PT. Bhumi Jati Power
Address PLTU Tanjung Jati B Unit 5&6 Tubanan, Kembang, Jepara - Jawa Tengah
Contract No. C-BJP-24-0014-OTH

Instrument Information

KKS No. 60LCA20AA210 Power Supply 380 VAC
Instrument Description CEP A OUTLET VALVE Stroke 329 mm
Manufacture ROTORK Inspection Date 04-06-2024
Model IQ25F14A
Serial Number N738301001
Instrument Location Turbin Lt. 1

Environment Condition

Temperature 27.6 °C Traveling Time
Humidity 38 % RH Open to Close 120.49 s
Close to Open 120.10 s

Stroke Result

Command	Local	Stroke	DCS FB
[%]	[%]	[mm]	[%]

Command	Feedback			
	Local		DCS	
	Open	Close	Open	Close
Close	-	OK	-	OK
Open	OK	-	OK	-

Visual Inspection

Leak Check OK Not OK Tightness Check OK Not OK
Corrosion Condition OK Not OK Accessories Check OK Not OK
Gearbox Condition OK Not OK

Remark

Test Equipment

Description	Serial Number	Certificate Number	Calibration Date
STOPWATCH CASIO	J011Q03	S. 23 004 599	27-03-2023
FIK-87-V MULTIMETER	16230349	S. 22 008 274	08-07-2022

Inspection Method

0007/SOP_BJS/2023
Procedure of Inspection Pneumatic and MOV

This certificate comprise of 1 page

Date of issue, 05-06-2024

Customer Signature,



Ayrtan Humardani Putradhi

HERVITAMA
Approved Signatory,



M. Teguh Nugroho

Calibrated by,



Suryo Wicaksono

Sertifikat ini berlaku untuk alat dengan nama, merek dan tipe / nomor seri yang dinyatakan diatas

This certificate applies only for the item specified above

Dilarang mengutip, memperbanyak dan / atau mempublikasikan isi sertifikat ini tanpa izin dari PT. Hervitama Indonesia
It is prohibited to copy, reproduce and / or publish the content of this Certificate without PT Hervitama Indonesia's approval

*Sertifikat ini sah bila dibubuhi cap PT. Hervitama Indonesia dan ditandatangani oleh pejabat yang berwenang

This certificate is valid if it has approved and signed by authorized person

