

## CERTIFICATE OF CALIBRATION PRESSURE TRANSMITTER

Certificate No. : 0384-24-HI-CAL-10C

### Customer Information

Company Name PT. Bhumi Jati Power  
Address PLTU Tanjung Jati B Unit 5&6 Tubanan, Kembang, Jepara - Jawa Tengah  
Contract No. C-BJP-24-0013-OTH

### Instrument Information

KKS No.	60LCA23CP005	Range	0 ~ 20
Instrument Description	CONDENSATE EXTRACTION PUMP OUTLET WATER PRESSURE 1	Unit	barg
Manufacture	YOKOGAWA	Out. Signal	4-20 mA
Model	EJX430A	Max. Error	0.5 %
Serial Number	91V703381	Cal. Date	09-05-2024
Instrument Location	TURBINE 1ST FLOOR		

### Environment Condition

Temperature 31.5 °C  
Humidity 66 % RH

### Calibration Result

Data Reading (Transmitter)											
As Found					As Left						
Input	Std Output	Output UUT	Deviation	Error	Result	Input	Std Output	Output UUT	Deviation	Error	Result
[barg]	[mA]	[mA]		[%]		[barg]	[mA]	[mA]		[%]	
-0.338	4.000	3.991	-0.009	-0.056	Pass						
4.668	8.000	7.999	-0.001	-0.006	Pass						
9.666	12.000	11.996	-0.004	-0.025	Pass						
14.665	16.000	15.994	-0.006	-0.038	Pass						
19.664	20.000	19.992	-0.008	-0.050	Pass						
19.664	20.000	19.992	-0.008	-0.050	Pass						
14.665	16.000	16.000	0.000	0.000	Pass						
9.664	12.000	11.988	-0.012	-0.075	Pass						
4.668	8.000	7.990	-0.010	-0.062	Pass						
-0.338	4.000	3.999	-0.001	-0.006	Pass						

### Standard Reference

Description	Serial Number	Certificate Number	Calibration Date
PRESSURE MODULE 700P08	14070813	S. 23 004 594	27-03-2023
Documenting Process Calibrator Fluke 754	3611011	S. 22 011 747	23-09-2023

### Calibration Method

0001/SOP\_BJS/2023  
Procedure of Calibration Pressure & Differential Transmitter

This certificate comprise of 1 page  
Date of issue, 10-05-2024

Customer Signature,



Ayrton Humardani Putradhi

HERVITAMA  
Approved Signatory,



M. Taufiq Nur Fitriyan

Calibrated by,



Handi Suryawinata

Sertifikat ini berlaku untuk alat dengan nama, merek dan tipe / nomor seri yang dinyatakan diatas  
This certificate applies only for the item specified above  
Dilarang mengutip, memperbanyak dan / atau mempublikasikan isi sertifikat ini tanpa izin dari PT. Hervitama Indonesia  
It is prohibited to copy, reproduce and / or publish the content of this Certificate without PT Hervitama Indonesia's approval  
\*Sertifikat ini sah bila dibubuhi cap PT. Hervitama Indonesia dan ditandatangani oleh pejabat yang berwenang  
This certificate is valid if it has approved and signed by authorized person

