

CERTIFICATE OF CALIBRATION DIFFERENTIAL PRESSURE TRANSMITTER

Certificate No. : 0474-26-HI-CAL-10

Customer Information

Company Name PT. Bumi Jati Power
Address PLTU Tanjung Jati B Unit 5&6 Tubanan, Kembang, Jepara - Jawa Tengah
Contract No. C-BJP-26-0004-OTH

Instrument Information

KKS No.	60LCA23CP005	Range	-0.336 ~ 19.664
Instrument Description	CONDENSATE EXTRACTION PUMP OUTLET WATER PRESSURE 1	Unit	bar g
Manufacture	YOKOGAWA	Out. Signal	4 - 20 mA
Model / Serial Number	EJX430A / 91V703381	Max. Error	0.5 %
Instrument Location	TURBINE 1ST FLOOR	Cal. Date	28-05-2026

Environment Condition

Temperature 31 °C Humidity 65 % RH

Calibration Result

Data Reading (Transmitter)											
As Found						As Left					
Input	Std Output	Output UUT	Deviation	Error	Result	Input	Std Output	Output UUT	Deviation	Error	Result
[bar g]	[mA]	[mA]		[%]		[bar g]	[mA]	[mA]		[%]	
-0.338	3.998	3.999	0.001	0.006	Pass						
4.661	7.997	8.004	0.007	0.044	Pass						
9.666	12.001	12.008	0.007	0.044	Pass						
14.665	16.000	16.009	0.009	0.056	Pass						
19.664	20.000	20.009	0.009	0.056	Pass						
14.665	16.000	16.009	0.009	0.056	Pass						
9.666	12.001	12.009	0.008	0.050	Pass						
4.661	7.997	8.005	0.008	0.050	Pass						
-0.331	3.998	4.000	0.002	0.013	Pass						

Visual Inspection (Checklist if OK)

Leak Check	☒	Tightness Check	☒	Corrosion Check	☒
Accessories Check	☒	Power Supply	☒		

Standard Reference

Description	Serial Number	Certificate Number	Calibration Date
DOCUMENTING PROCESS CALIBRATOR FLUKE 754	56070038	MAL 26031230	06-03-2026
FLUKE PRESURE MODULE 700P08	14070813	MAL 26031235	03-03-2026

Calibration Method

0001/SOP_BJS/2025
Standard Operating Procedure of Calibration Pressure & Differential Transmitter

This certificate comprises 2 pages
Date of issue, 03-06-2026

Customer Signature,



Ayrtan Humardani Putradhi

Approved Signatory,
HERVITAMA



Akhmad Nashoikhuddin

Calibrated by,



Akhmad Nashoikhuddin

Sertifikat ini berlaku untuk alat dengan nama, merek dan tipe / nomor seri yang dinyatakan diatas

This certificate applies only for the item specified above

Tidak dibenarkan mempublikasikan/memperbanyak sebagian isi sertifikat ini tanpa ijin PT. Hervitama Indonesia

This certificate shall not be produced/reproduced except in full without the written approval of PT. Hervitama Indonesia

*Sertifikat ini sah bila dibubuhi cap PT. Hervitama Indonesia dan ditandatangani oleh pejabat yang berwenang

This certificate is valid if it has approved and signed by authorized person