

CERTIFICATE OF CALIBRATION PRESSURE TRANSMITTER

Certificate No. : 0386-24-HI-CAL-10C

Customer Information

Company Name PT. Bhumi Jati Power
Address PLTU Tanjung Jati B Unit 5&6 Tubanan, Kembang, Jepara - Jawa Tengah
Contract No. C-BJP-24-0013-OTH

Instrument Information

KKS No. 60LCA54CP005 Range 0 ~ 50
Instrument Description CONDENSATE BOOSTER PUMP OUTLET WATER Unit barg
Manufacture YOKOGAWA Out. Signal 4-20 mA
Model EJX430A Max. Error 0.5 %
Serial Number 91V703384 Cal. Date 09-05-2024
Instrument Location TURBINE 1ST FLOOR

Environment Condition

Temperature 31.5 °C
Humidity 66 % RH

Calibration Result

As Found						As Left					
Input	Std Output	Output UUT	Deviation	Error	Result	Input	Std Output	Output UUT	Deviation	Error	Result
[barg]	[mA]	[mA]		[%]		[barg]	[mA]	[mA]		[%]	
0.000	4.000	3.996	-0.004	-0.025	Pass						
12.500	8.000	7.992	-0.008	-0.050	Pass						
25.000	12.000	11.993	-0.007	-0.044	Pass						
37.501	16.000	15.996	-0.004	-0.025	Pass						
50.001	20.000	19.996	-0.004	-0.025	Pass						
50.001	20.000	19.996	-0.004	-0.025	Pass						
37.501	16.000	15.994	-0.006	-0.038	Pass						
25.000	12.000	11.993	-0.007	-0.044	Pass						
12.500	8.000	7.997	-0.003	-0.019	Pass						
0.000	4.000	3.998	-0.002	-0.012	Pass						

Standard Reference

Description	Serial Number	Certificate Number	Calibration Date
PRESSURE MODULE 700P08	14070813	S. 23 004 594	27-03-2023
Documenting Process Calibrator Fluke 754	3611011	S. 22 011 747	23-09-2023

Calibration Method

0001/SOP_BJS/2023
Procedure of Calibration Pressure & Differential Transmitter

This certificate comprise of 1 page
Date of issue, 10-05-2024

Customer Signature,



Ayrton Humardani Putradhi

HERVITAMA
Approved Signatory,



M. Taufiq Nur Fitriyan

Calibrated by,



Handi Suryawinata

Sertifikat ini berlaku untuk alat dengan nama, merek dan tipe / nomor seri yang dinyatakan diatas
This certificate applies only for the item specified above
Dilarang mengutip, memperbanyak dan / atau mempublikasikan isi sertifikat ini tanpa izin dari PT. Hervitama Indonesia
It is prohibited to copy, reproduce and / or publish the content of this Certificate without PT Hervitama Indonesia's approval
*Sertifikat ini sah bila dibubuhi cap PT. Hervitama Indonesia dan ditandatangani oleh pejabat yang berwenang
This certificate is valid if it has approved and signed by authorized person

